


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction C 1/4 SE 1/4 NE 1/4	Section number 21	Township number T 20 S	Range number R 17 E/W
2. Distance and direction from nearest town or city: 4W 8N of Larned Street address of well location if in city:			3. Owner of well: Bruce Weisensel R.R. or street: RR 1 City, state, zip code: Larned Ks.			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: 			
5. Type and color of material			From	To	6. Bore hole dia. 9 in. Completion date _____ Well depth 85 ft. 10-19-76	
Top Soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Brown Clay			3	33	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Soft Sandy Clay			33	46	9. Casing: Material 4 1/2 Height: Above or <u>below</u> Threaded _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia 4 1/2 in. to 85 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 4	
Clay			46	60	10. Screen: Manufacturer's name _____ Type pb pvc Dia. 4 1/2 Slot/gauge 1/32 Length 25 Set between 60 ft. and 85 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 3/4 1 1/2	
Soft Sand and Caly			60	71	11. Static water level: _____ mo./day/yr. 34 ft. below land surface Date 10-19-76	
Clay and Sand Gravel			71	85	12. Pumping level below land surfaces: 34 ft. after 1 hrs. pumping 20 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.	
Sand Gravel and Caly			79	85	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10-19-76	
					14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
					15. Well grouted? _____ With: _____ Neat cement _____ Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
					16. Nearest source of possible contamination: ft. 200 Direction SW Type septic Tank Well disinfected upon completion? _____ Yes _____ No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: _____ Submersible _____ Turbine _____ Jet _____ Reciprocating _____ Centrifugal _____ Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. Signed Thedia Nodden Date 10/29/76 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: _____ Hill _____ Slope <input checked="" type="checkbox"/> Upland _____ Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5