

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 2	Township number T 20 S R 19 E W	Range number 19
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: Louis Dellett R.R. or street: RR City, state, zip code: Rush Center, Ks.			
4. Locate with "X" in section below:			Sketch map: shed		6. Bore hole dia. 6 in. Completion date 9-20-79 Well depth 340 ft.	
					7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material			From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
topsoil			0	4	9. Casing: Material PVC Height: Above or 300 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 16 in. RMP 5 PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 340 ft. depth Wall Thickness: 1/8 in. or Dia. 5 in. to 340 ft. depth gage No. .28	
rock and clay			4	36	10. Screen: Manufacturer's name JTC stream Type pvc Dia. 5 Slot/size 031 Length 20 Set between 320 ft. and 340 ft. ft. and 3 1/2 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/8	
shale			36	220	11. Static water level: 160 ft. below land surface Date 9-20-79 mo./day/yr.	
white dakota clay with streaks of red clay			220	305	12. Pumping level below land surfaces: 160 ft. after 3 hrs. pumping 15 g.p.m. ft. after 15 hrs. pumping 15 g.p.m. Estimated maximum yield 15 g.p.m.	
sandstone			305	340	13. Water sample submitted: X Yes <input checked="" type="checkbox"/> No Date	
					14. Well head completion: 16 inches above grade <input type="checkbox"/> Pitless adapter	
					15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 14 ft.	
					16. Nearest source of possible contamination: 500 ft. Direction west Type stock yard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name E. Hiway 40 Hays, Ks. License No. Address 114 Signed Neil Kurst Date 9-20 Authorized representative	
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

20
 T
 R
 E
 W
 19
 Sec
 2
 1/4
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5