

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Pawnee	Fraction SW 1/4 SW 1/4 SW 1/4	Section number 10	Township number T 20 S R 19 E/W	Range number
2. Distance and direction from nearest town or city 10 south 5 west 1 north 1 west of Rush Center, Ks. Street address of well location if in city:				3. Owner of well: Adolph Snodgrass R.R. or street: RR Rozell, Ks. City, state, zip code:		
4. Locate with "X" in section below: Sketch map: Road				6. Bore hole dia. 8 in. Completion date 11-8-79 Well depth 410 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material				9. Casing: Material PVC Height: Above or below 20 Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 200 in. RMP: 5 PVC <input checked="" type="checkbox"/> Weight 200 lbs./ft. Dia. 5 in. to 410 ft. depth Wall Thickness: inches or Dia. 5 in. to 410 ft. depth gage No. 26		
				10. Screen: Manufacturer's name Jet stream Type pvc Dia. 5 Slot/gage 031 Length 20 Set between 390 ft. and 410 ft. ft. and 410 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/4-3/8		
topsoil				11. Static water level: 240 ft. below land surface Date 11-8-79 ms./day/yr.		
clay				12. Pumping level below land surfaces: 250 ft. after 2 hrs. pumping 15 g.p.m. ft. after 2 hrs. pumping 15 g.p.m. Estimated maximum yield 15 g.p.m.		
shale				13. Water sample submitted: 240 mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
white dakota clay				14. Well head completion: 20 inches above grade <input type="checkbox"/> Pitless adapter		
red clay				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
white dakota clay				16. Nearest source of possible contamination: 300 ft. South Direction South Type sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
sandstone				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Karst Water Well 199 Business name Karst Water Well License No. _____ Address E. Highway 40 Hays, Ks. Signed Mike Karst Date 11-8-79 Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley						

20 19 10
 Sec 10
 SW 1/4 SW 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5