


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County McPherson	Township name Lone Tree	Fraction NE$\frac{1}{4}$NE$\frac{1}{4}$SE$\frac{1}{4}$	Section number 29	Town number 20	Range number 2W		
Distance and direction from nearest town or city: 3Mi. East 1/2 Mi. South Of Elyria			3 Owner of well: Harvey Koehn R.R. 2 Galva, Kansas Address:					
Locate with "X" in section below: N  W E S 1 Mile			Sketch map:			4 Well depth: 60 ft. Date of completion 5-5-75 Well diameter 9 in.		
2 Type and color of material			From	To	5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Yellow Clay		0	20	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
			Fine Sand		20	25	7 Casing: Material Plastic Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18 in. Diam. Class 160 Weight 160 lbs./ft. 5 in. to 60 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth	
			Yellow Clay		25	40	8 Screen: Certain-Teed Manufacturer Plastic Dia. 5In. Type 1/16 Slot/gauze 10 Length Set between 50 ft. and 60 ft. Fittings: 1/8 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material	
			Fine Sand		40	45	9 Static water level: 30 ft. below land surface Date 5-5-75	
			Red Clay		45	50	10 Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
			Course Sand		50	59	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
			BlueShale		59	60	12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
							13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
							14 Nearest source of possible contamination: ft. 75 Direction North Type Pasture Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
(use a second sheet if needed)					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			16 Remarks: elevation		17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhus Drilling 180 Business name Tampa, Kansas License No. Address South 24th Date 5-19-75 Signed South 24th Authorized representative			
			Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					