

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County PAWNEE	Township name SHILEY	Fraction SW 1/4	Section number 21	Town number 20	Range number 20
Distance and direction from nearest town or city: <i>Nurdett</i>			3 Owner of well: FRANKLIN NELSON			
Street address of well location if in city:			Address: BURDETT KANSAS			
Locate with "X" in section below:		Sketch map:		4 Well depth: 29 53 ft. Date of completion 29 July 75 Well diameter 16 in.		
		5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/> _____		
				7 Casing: Material STEEL Weight: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 16 in. to 53 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Weight 70 lbs./ft.		
2 Type and color of material				From	To	8 Screen:
TOP SOIL				0	4	Manufacturer WADSWORTH
SAND				4	16	Type STEEL Dia. 16
CLAY TAN				16	34	Slot/gauze 48 Length 40
SAND - SOME CLAY				14	55	Set between 32 ft. and 92 ft.
CLAY				55	65	Fittings:
TIGHT ROCKY SAND + CLAY				65	80	Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2 DOWN
SHALE				80	95	9 Static water level: 14 ft. below land surface Date 29 July 1975
						10 Pumping level below land surfaces: 82 ft. after 6 hrs. pumping 550 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 375 g.p.m.
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
						12 Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 12 ft.
						14 Nearest source of possible contamination: WIL ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould Model number 6" HP _____ Volts _____ Length of drop pipe 85 ft. capacity 550 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
16 Remarks: elevation 26863				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRPC Business name _____ License No. 2-43 Address: HANSTON KANSAS Signed Dean Waterhouse Date 30 Aug 75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5