

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County PAWNEE	Fraction 1/4 SE 1/4 SW 1/4	Section number 33	Township number T 20 S R 20 E/W	Range number
2. Distance and direction from nearest town or city: 5 mi. N. 1/8 mi. W of Burdett, Ks. Street address of well location if in city:			3. Owner of well: LEON STEFFEN R.R. or street: NONE City, state, zip code: Burdett, Kans. 67529		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 1 1/2 in. Completion date _____ Well depth 50 ft. 10-6-77	
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
5. Type and color of material		From	To	9. Casing: Material PVC Height: Above or below _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 1 1/2 in. to 50 ft. depth Wall Thickness: inches or _____ Dia. _____ in. to _____ ft. depth Gauge No. 237	
Top soil		0	3	10. Screen: Manufacturer's name Certain-Feed Type PVC Dia. _____ Slot/gauze 1/16 Length 20 Set between 30 ft. and 30 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 15 3/4 3/8	
Clay		3	25	11. Static water level: _____ mo./day/yr. 26 ft. below land surface Date 10-5-77	
Clay rock and sand		25	42	12. Pumping level below land surfaces: 45 ft. after 1 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Sandy clay		42	50	13. Water sample submitted: _____ mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 10-5-77	
Shale		50		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade	
				15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: ft. 300 Direction NW Type septic Well disinfected upon completion? HTH Yes <input type="checkbox"/> No <input type="checkbox"/>	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Basenroantz-Bemis 134 Business name _____ License No. _____ Address Great Bend, Ks. 67530 Signed [Signature] Date 10-17-77 Authorized representative	
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley					

T 20 S
 R 20 W
 Sec 33
 SE 1/4 SW 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5