

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

CAC
WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SW NE SW

1 Location of well:	County NESS	Township name HIGH POINT	Fraction SW 1/4	Section number 3	Town number 20	Range number 21
Distance and direction from nearest town or city: 1 1/2 MI SOUTH 3/4 EAST OF BAZINE R				3 Owner of well: HARRY SHANK		
Street address of well location if in city:				Address: BAZINE KANSAS		
Locate with "X" in section below:		Sketch map:		4 Well depth: 25 ft. Date of completion 24 Jan 75 Well diameter 8 in.		
				5 <input type="checkbox"/> Coble tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
2		Type and color of material		From		To
		Light tan sand & tan clay		0		12
		Light brown clay with white rock		12		18
		fine loose sand		18		21
		Tan clay then shale		21		27
		BRICK 25				
		18				
		17' salt				
		in Alluvium				
		(use a second sheet if needed)				
16 Remarks: elevation		2242 25 2217		8 Screen: Manufacturer JESSET & LOWELL Type STYRENE Dia. 5" Slot/gauze FINE Length 10 Set between 15 ft. and 25 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material #4		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				9 Static water level: 18 ft. below land surface Date 24-Jan-75		
				10 Pumping level below land surfaces: 16 ft. after 1 1/2 hrs. pumping 5 g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 29 inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> ____ Depth: From 0 ft. to 13 ft.		
				14 Nearest source of possible contamination: ft. 100 Direction SOUTH Type POND Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe 21 ft. capacity ____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal 2 1/2" Other Cylinder		
				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Watten Chully 243A Business name _____ License No. _____ Address Hanston Kansas Signed Dean Watten Date 25 Jan 75 Authorized representative		