



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

mess city

1. Location of well:	County Ness	Fraction SE 1/4 SE 1/4 SE 1/4	Section number 19	Township number T 20 S	Range number R 22 E
2. Distance and direction from nearest town or city: 11S 6E of Ness City Street address of well location if in city:			3. Owner of well: Larry Reinert R.R. or street: Ness City, Kansas 67560 City, state, zip code:		
4. Locate with "X" in section below: 			Sketch map: 		
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 11-7-78 Well depth 88 ft.		
Topsoil			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
Clay white			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Sand			9. Casing: Material steel Height: 12 in. or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft.		
Clay white			Dia. 16 in. to 48 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
Sand			10. Screen: Manufacturer's name Doer Metal Type Steel Dia. 16 in. Slot gauze 1/8 Length 40 Set between 48 ft. and 88 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/8-1/4		
Sandy clay			11. Static water level: <input type="checkbox"/> mo./day/yr. 47 ft. below land surface Date 9-12-78		
			12. Pumping level below land surfaces: 76 ft. after 4 hrs. pumping 500 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 650 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 14 ft.		
			16. Nearest source of possible contamination: ft. 2600 Direction W Type well Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Western Land Roll Model number 678365 HP 20 Volts 480 Length of drop pipe 80 ft. capacity 500 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. Drilling Business name Jetmore License No. 130 Address Jetmore Signed Dale Knoefler Date 11-15-78 Authorized representative		
19. Remarks: Concrete slab was installed					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5