

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

CAC
WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

SW N1 SW

Wiggins 1111

1 Location of well:	County MISSOURI	Township name HIGH POINT	Fraction SW 1/4	Section number 34	Town number 20	Range number 22		
Distance and direction from nearest town or city: 10 MILES NORTH 1 1/2 WEST FROM KANSTON			3 Owner of well: ROBERT PFAFF Address: JETMORE					
Locate with "X" in section below: N W E S 1 Mile			Sketch map: 			4 Well depth: 98 ft. Date of completion OCT 75 Well diameter 16 in.		
2 Type and color of material			Prom. To			5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>					
BLACK TOPSOIL RED CLAY STRIPE BLUE CLAY SAND - COARSE CLAY SOFT BLUE SAND MEDIUM TO FINE TOP SOIL + CLAY SAND - SOME CLAY BLUE CLAY COARSE SAND + GRAVEL RAINBOW CLAY in Alluvium			7 Casing: Material STEEL Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 18 in. Diam. 16 in. to 16 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No In. to 16 ft. depth			8 Screen: WABROWN ENTERPRISE Manufacturer WABROWN ENTERPRISE Type STEEL Dia. 16 in. Slot/gauze 1/8 in. Length 60 Set between 38 ft. and 78 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 3/8 to 1/2 Static water level: 38 ft. below land surface Date 4-OCT-75		
			10 Pumping level below land surfaces: 72 ft. after 6 hrs. pumping 1250 g.p.m. 73 ft. after 16 hrs. pumping 1650 g.p.m. Estimated maximum yield 1650 g.p.m.			11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 4-OCT-75		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley 2170 96 2074			12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Cement Depth: From 0 ft. to 4 ft.		
			14 Nearest source of possible contamination: ft. 60 Direction NORTH Type RAVINE Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. DEAN WATERHOUSE DRILLING Business name _____ License No. _____ Address KANSTON KANSAS Signed Dean Waterhouse Date 10-11-75 Authorized representative								

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5