

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

miss city NW

BBE

1. Location of well:		County Ness	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 8	Township number T 20 S R 23 E/W	Range number
2. Distance and direction from nearest town or city: 7 mi. south from Ness City.			3. Owner of well: Homer Delaney R.R. or street: City, state, zip code: Ness City, Kansas 67560			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 410 ft. 9/10/79		
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
brown clay			40	9. Casing: Material _____ Height: Above or _____ Threaded _____ Welded _____ Surface 18 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 380 ft. depth Wall thickness: inches or Dia. 5 in. to 380 ft. depth gage No. 2001b.		
tan rocky sandy clay			40	10. Screen: Manufacturer's name _____ Jet Stream Type PVC Dia. 5" Slot/gauze 1/16 Length 30' Set between 360 ft. and 370 ft. 390 ft. and 410 ft. Gravel pack? yes Size range of material #1		
black shale			46	11. Static water level: _____ mo./day/yr. 161 ft. below land surface Date 8/20/79		
multi-colored clays or shales			85	12. Pumping level below land surfaces: 165 ft. after 48 hrs. pumping 8 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 plus g.p.m.		
show of fine hard sandstone			295	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No _____ Date _____		
multi colored clays and shales			306	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade		
traces of sandstone			366	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From 4 ft. to 60 ft.		
light colored clay or shale			370	16. Nearest source of possible contamination: sewer line ft. 70 Direction sw Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____		
sandstone clean and hard			395	17. Pump: _____ Not installed Manufacturer's name Aeromotor Model number SD12100 HP 1 Volts 230 Length of drop pipe 210 ft. capacity 10 g.p.m. Type: <input checked="" type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____		
red clay			410	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse Drilling 243 Business name _____ License No. _____ Address Honston, Kansas Signed Dean Waterhouse Date 9/13/79 Authorized representative		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		50' of 8 3/8" pipe cemented in place to hold out sheet water at 45 ft. 5" PVC cemented from 60 ft. up to -4ft.				
		BBE 46'				
		CRETACEOUS W.P.V.				
		2313				
		(Use a second sheet if needed)				

20
23
20
8
1/4
1/4
1/4
1/4
 Sec
 NW 1/4 NW 1/4 NW 1/4 NW 1/4