

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County Ness	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 24	Township number T 20 S R 23 E W	Range number 23
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: R.R. or street: City, state, zip code:			
2. Distance and direction from nearest town or city: IOS, 4 1/2 E Of Ness City,			Don Dansel Jetmore, Kansas 67854			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 4-26-76 Well depth 15 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Clay		25		9. Casing: Material p.l.s. Height: Above or below Threading: Welded 12 in. RMP <input checked="" type="checkbox"/> PVC 81 Weight lbs./ft. Dia. 5 in. to 55 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 0.250		
Sand		50		10. Screens: Manufacturer's name Sunflower Plastics Pipe, Inc. Type RMP Dia. 5 in. Slot/gauze 1/16 Length 20 Set between 55 ft. and 75 ft. Gravel pack? Yes Size range of material 1/8-1/4		
Clay		55		11. Static water level: 45 ft. below land surface Date 4-26-76		
Sand		66		12. Pumping level below land surfaces: 45 ft. after 1 hrs. pumping 20 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 200 g.p.m.		
Clay		68		13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Sand		75		14. Well head completion: Pitless adapter 12 inches above grade		
BROCK ?				15. Well grouted? yes With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 20 ft. to 0 ft.		
				16. Nearest source of possible contamination: ft. 90 Direction NE Type old well Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
				17. Pump: Not installed Manufacturer's name Aermotor Model number SD 12 HP 1/2 Volts 230 Length of drop pipe 63 ft. capacity 15 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
2201				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Knoefler Bros. Drilling Business name Jetmore License No. 190 Address Jetmore Signed Dale Knoefler Date 5-10-76 Authorized representative		
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Old well concrete Concrete slab was installed				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-5