


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Ness	Township name Franklin	Fraction NE SW 1/4 of NW 1/4	Section number 27	Town number T-20-S	Range number R-23-W
Distance and direction from nearest town or city: 10 mi. south and 2 mi. east of Ness City Street address of well location if in city:				3 Owner of well: Frusher & Frusher Address: Ness City, Kansas		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 253 ft. Date of completion 11-18-75 Well diameter 28 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
Surface				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Brown clay				7 Casing: Material Metal Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 30-12 in. Diam. 16 in. to 253 ft. depth/Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to in. ft. depth		
A-1 sand and gravel				8 Screen: W.A. Brown Manufacturer Type Free Flo Dia. 16" Slot/gauze 1/8 Length 2" Set between 111 ft. and 251 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material CMA		
Brown and blue clay				9 Static water level: 47 ft. below land surface Date 11-17-75		
Good sand and big flat gravel				10 Pumping level below land surfaces: 115 ft. after 2 hrs. pumping 1900 g.p.m. 145 ft. after 1/2 hrs. pumping 1700 g.p.m. Estimated maximum yield 2200 g.p.m.		
Blue and gray shale with rock layers				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
Tan sandstone with 25% shale mixed				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
A-1 tan sandstone				13 Well grouted? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From ft. to ft.		
Gray shale				14 Nearest source of possible contamination: NA ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
(Well drilled for Dean Waterhouse Drilling)				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Grouting will be handled by him				16 Remarks: elevation 2217 Block 59 47 12' sand thick 2211 2152 ✓		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International Inc. 190 Business name License No. Address Dodge City, Kansas Signed Carl G. Fitch Date 11-18-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5