


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

ADC

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

SW

1. Location of well:	County NESS	Fraction SW SE NE 1/4 1/4 1/4	Section number 28	Township number T 20 S R 23 E/W	Range number
2. Distance and direction from nearest town or city: Street address of well location if in city:	11-12 SOUTH + 1 1/2 MI EAST FROM NESS, CITY				
3. Owner of well: R.R. or street: City, state, zip code:	FRED BURDETT NESS CITY KANSAS				
4. Locate with "X" in section below: Sketch map:	6. Bore hole dia. 8" in. Completion date 12-1-66 Well depth 185 ft. Aug-76				
	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
5. Type and color of material	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24" in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 2" in. to 155 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. 320				
TAN CLAY	10. Screen: Manufacturer's name WEL Type WEL Dia. 5" Slot/gauze 1/4" Length 30" Set between 155 ft. and 185 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material #1				
STRIP OF FINE SAND	11. Static water level: 68 ft. below land surface Date AUG 76				
SOFT TAN CLAY	12. Pumping level below land surfaces: ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 120 g.p.m.				
SAND-FINE (SOME CLAY)	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date Aug 76				
RAINBOW CLAY + SHALE	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade				
SANDSTONE (HARD + FINE)	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 4 ft. to 15 ft.				
LIGHT COLORED CLAY	16. Nearest source of possible contamination: ft. 75 Direction N Type old well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No				
ALTERNATE LAYERS OF SAND STONE + CLAY	17. Pump: Manufacturer's name RED Model number 5090A1 1/2 Volts 220 Length of drop pipe 105 ft. capacity 9 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
GOOD SANDSTONE VERY LITTLE CLAY	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 203 Business name Dean Water House Drilling License No. 1/4 1/4 1/4 Address HANSTON, KANSAS Signed Dean Water House Date Oct 76 Authorized representative				
RED CLAY	18. Elevation:				
BRICK 34'	19. Remarks: WE SET 38 FT 8 1/8" STEEL PIPE 7' BELOW GROUND LEVEL AND CEMENTED WITH 10 SC CEMENT TO STOP SURFACE WATER TOP 24" DRILLER WITH 10" BIT.				
CRETACEOUS					
WELL (Use a second sheet if needed)					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5