

USE TYPEWRITER OR BALL POINT PEN-PRESS FINELY PRINT CLEARLY

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

new city m

BR 12

1. Location of well: <i>NESS</i>		Fraction <i>NW</i> 1/4	<i>NW</i> 1/4	<i>NW</i> 1/4	Section number <i>36</i>	Township number T <i>20</i> S R <i>23</i> E <i>(N)</i>	Range number
2. Distance from nearest town or city: <i>11 MILES SOUTH 4 MILE EAST FROM NESS CITY</i>				3. Owner of well: <i>ALICE REINERT</i>			
Street address of well location if in city: <i>NESS CITY</i>				R.R. or street: City, state, zip code: <i>NESS CITY KANSAS 67560</i>			
4. Locate with "X" in section below: N W E S 1 Mile				Sketch map: 			
5. Type and color of material				From	To	6. Bore hole dia. <i>8</i> in. Completion date <i>18</i> Well depth <i>286</i> ft. <i>NOV 1976</i>	
<i>BROWN CLAY</i>				<i>0</i>	<i>32</i>	7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
<i>FINE SAND</i>				<i>32</i>	<i>48</i>	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
<i>BLUE SHALE</i>				<i>48</i>	<i>115</i>	9. Casing: Material <input type="checkbox"/> Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <i>16</i> in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <i>190</i> lbs./ft. Dia. <i>105</i> in. to <i>256</i> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <i>120</i>	
<i>SHALE + SHELL ROCK</i>				<i>115</i>	<i>126</i>	10. Screen: Manufacturer's name Type <i>RMP</i> Dia. <i>5"</i> Slot/gauze <i>1/16</i> Length <i>30'</i> Set between <i>256</i> ft. and <i>286</i> ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <i>#1</i>	
<i>FIRE CLAY</i>				<i>126</i>	<i>200</i>	11. Static water level: <input type="checkbox"/> mo./day/yr. <i>72</i> ft. below land surface Date <i>18 NOV 76</i>	
<i>SANDSTONE + SHALE STRIPS</i>				<i>200</i>	<i>230</i>	12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <i>1007</i> g.p.m.	
<i>GREY SHALE + PYRITE</i>				<i>230</i>	<i>254</i>	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
<i>GOOD CLEAN SANDSTONE</i>				<i>254</i>	<i>285</i>	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> inches above grade	
<i>RED CLAY</i>				<i>285</i>	<i>290</i>	15. Well grouted? <i>YES</i> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <i>4</i> ft. to <i>12</i> ft.	
<i>CRETACEOUS WELL</i>						16. Nearest source of possible contamination: ft. <i>28</i> Direction <i>NE</i> Type <i>WELL PIT</i> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
<i>2706</i> <i>48</i> <i>2160</i> (Use a second sheet if needed)						17. Pump: Not installed Manufacturer's name <i>REDA</i> Model number <i>909057</i> HP <i>1/2</i> Volts <i>110</i> Length of drop pipe <i>105</i> ft. capacity <i>12</i> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: <i>WE SET 51 FT 8 5/8" STEEL PIPE 4 FT BELOW SURFACE & CEMENTED IN PLACE TO HOLD OUT SURFACE WATER</i>					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <i>243</i> <i>DEAN WATERHOUSE PRL 5</i> Business name License No. Address <i>HANSTON KANSAS</i> Signed <i>Dean Waterhouse</i> Date <i>79</i> Authorized representative	

20 230 36
R
Sec
1/4 1/4 1/4