

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

ARK

beuler sw

1. Location of well: County Ness		Fraction NW 1/4 NW 1/4 NE 1/4	Section number 30	Township number T 20 S R 26	Range number E/W
2. Distance and direction from nearest town or city: 1 1/2 mi. south and 18 1/2 mi. west from Ness City			3. Owner of well: Warren Sherwin		
Street address of well location if in city:			City, state, zip code: Beeler Kansas 67518		
4. Locate with "X" in section below:		Sketch map:			
		<p>6. Bore hole dia. 8 in. Completion date 10/22/79</p> <p>Well depth 60 ft.</p> <p>7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary</p> <p>8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other</p> <p>9. Casing: Material _____ Height: Above or _____ Threading: _____ Welded _____ Surface 12 in. RMP _____ PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 0 in. to 50 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. sch 40</p>			
5. Type and color of material:		From	To		
brown clay		0	27	10. Screen: Manufacturer's name Jet Stream	
sand and white rock some clay		27	36	Type PVC Dia. 5" Slot/gauze 1/16 Length 10' Set between 50 ft. and 60 ft. ft. and _____ ft. Gravel pack Yes Size range of material #1	
blue clay		36	52	11. Static water level: _____ mg./day/yr. 32 ft. below land surface Date 10/22/79	
fine blue sand and clay		52	59	12. Pumping level below land surfaces: 35 ft. after 1 hrs. pumping 12 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 60 g.p.m.	
blue shale		59	65	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____	
BRock 59				14. Well head completion: _____ Pitless adapter 12 Inches above grade	
32				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement _____ Bentonite _____ Concrete _____ Depth: From -3 ft. to -15 ft.	
27' set back				16. Nearest source of possible contamination: ft. 20 Direction SW Type tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No _____	
Alluvium				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible _____ Turbine _____ <input type="checkbox"/> Jet _____ Reciprocating _____ <input type="checkbox"/> Centrifugal _____ Other _____	
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Dean Waterhouse Drilling 243 Business name License No. _____ Address Hanston, Kansas Signed Dean Waterhouse Date 10/31/79 Authorized representative	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	2493 59 2434				

T
R
E
S
E
C
1/4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5