

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 6	Township number T 20 S	Range number R 3 E
2. Distance and direction from nearest town or city: Southwest of City Street address of well location if in city:			3. Owner of well: City of McPherson R.R. or street: City Building City, state, zip code: McPherson, Kansas 67460		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: Monitor Well No. 4-77		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 3/17/77 Well depth 211 ft.
Top soil			0	2	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown clay			2	50	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other
Med. to co. sand & gravel			50	68	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 2.0 lbs./ft. Dia. 4 in. to 186 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 0.237"
Med. to co. sand & gravel w/clay lenses			68	107	10. Screen: Manufacturer's name Layne Type Slotted Dia. 4" Slot/gauze 0.100" Length 20' Set between 186 ft. and 206 ft. Gravel pack? yes Size range of material 1/8-1/4
Med. to co. sand & gravel			107	113	11. Static water level: 75.0 ft. below land surface Date 3/16/77 mo./day/yr.
Tan clay			113	116	12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.
Med. fine to co. sand to med. gravel			116	130	13. Water sample submitted: X Yes <input type="checkbox"/> No Date 3/16/77 mo./day/yr.
Tan-gray clay			130	137	14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
Med. to co. sand to med. gravel			137	148	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Gray clay			148	168	16. Nearest source of possible contamination: ** ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Med. to co. sand to med. co. gravel			168	206	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Blue-gray shale			206	211	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne Western Co. 102 Business name License No. Address Wichita, Kansas Signed [Signature] Date 4-5-77 Authorized representative
18. Elevation: 1494+- Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: ** Not determined		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5