


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

20 3W 18 CW
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County <u>McPherson</u>	Township name <u>King City</u>	Fraction <u>NW 1/4</u>	Section number <u>18</u>	Town number <u>20 S</u>	Range number <u>R-3-W</u>			
Distance and direction from nearest town or city: <u>3 miles</u>			3 Owner of well: <u>ROONEY I. SWANSON</u>						
Street address of well location if in city: <u>So. of McPherson</u>			Address: <u>RT 1 McPherson, KS</u>						
Locate with "X" in section below: 		Sketch map: <u>Well in center of N.W. 1/4</u>		4 Well depth: <u>207</u> ft. Date of completion: <u>10-9-75</u> Well diameter <u>30"</u> in.					
2		Type and color of material		From		To		5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
								6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
								7 Casing: Material <u>Galv</u> Height: above/below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>207</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No Weight <u>30</u> lbs./ft.	
								8 Screen: Manufacturer <u>AURORA TILE CO</u> Type <u>TRANSITE</u> Dia. <u>14" I.P.</u> Slot/gauze <u>1/8</u> Length <u>52 ft.</u> Set between <u>155</u> ft. and <u>207</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/4"</u>	
								9 Static water level: <u>72</u> ft. below land surface Date <u>10-4-75</u>	
						10 Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield <u>1500</u> g.p.m.			
						11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____			
						12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
						13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Grouted clay Depth: From <u>0</u> ft. to <u>22</u> ft.			
						14 Nearest source of possible contamination: ft <u>1300</u> Direction <u>NW</u> Type <u>well</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
						15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>WESTERN LAND ROVER</u> Model number <u>8M</u> HP <u>60</u> Volts ____ Length of drop pipe <u>130</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
						16 Remarks: elevation <u>1985</u> Topo Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			
						17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Peterson Bros Inc.</u> <u>2nd</u> <u>138</u> Business name License No. Address <u>Lawrence, Kansas</u> Signed <u>Walter Peterson</u> Date <u>10-13-75</u> Authorized representative			

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5