


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82g-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: McPherson	County Sw 1/4 Sw 1/4 Sw 1/4	Fraction 23	Section number T 20 S R 3 E 10	Township number S 20	Range number R 3
2. Distance and direction from nearest town or city: in Elyria Street address of well location if in city:			3. Owner of well: Harry Temple R.R. or street: Box 34 City, state, zip code: Newton Ks.		
4. Locate with "X" in section below: N W E S 1 Mile		Sketch map:		6. Bore hole dia. 9 in. Completion date 9-9-76 Well depth 85 ft.	
		7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
		9. Casing: Material PVC Height: Above or below surface 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 30 lbs./ft. Dia. 5 in. to 25 ft. depth Wall Thickness: inches 1.25 Dia. 5 in. to 25 ft. depth gage No. 1238			
5. Type and color of material			From	To	10. Screen: Manufacturer's name Certain Feed Type PVC Dia. 5" Slot/gauze 1/8" Length 10' Set between 193 ft. and 83 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4-30
Top Soil			0	2	11. Static water level: _____ ma./day/yr. 60 ft. below land surface Date 9-9-76
Yellow Clay			2	24	12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Fine Sand			24	26	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
Bed + yellow clay			26	82	14. Well head completion: 12 Inches above grade Pitless adapter <input checked="" type="checkbox"/>
Medium Sand			82	85	15. Well grouted? <input checked="" type="checkbox"/> With: Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete <input type="checkbox"/> Depth: From 0 ft. to 10 ft.
Bed Shale					16. Nearest source of possible contamination: Septic Tank ft. 60 Direction NW Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation:
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhaus Drilling Business name _____ License No. _____ Address _____ Signed Paul Backhaus Date 9-13-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5