


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

X Location of well:		County	Fraction	Section number	Township number	Range number
McPherson		Se 1/4 Se 1/4 Se 1/4	25-	T 20	S R 3	E (W)
Distance and direction from nearest town or city:		3. Owner of well:				
IS 1 1/4 W		Arbo Flickner				
Street address of well location if in city:		R.R. or street:				
Elyria		BR 1				
		City, state, zip code: McPherson Ks. 67460				
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 10 in. Completion date		
				Well depth 91 ft. 5-24-76		
5. Type and color of material		From	To	7. Cable tool X Rotary Driven Dug		
Top Soil		0	2	Hollow rod Jetted Bored Reverse rotary		
yellow clay		2	32	8. Use: X Domestic Public supply Industry		
fine Sand		32	38	Irrigation Air conditioning Stock		
yellow + Red clay		38	76	Lawn Oil field water Other		
Medium Sand		76	86	9. Casing: Material PVC Height: Above or below		
Red Shale		86	91	Threaded Welded Surface 16 in.		
				RMP PVC X Weight 5440 lbs./ft.		
				Dia. 5 in. to 91 ft. depth Wall Thickness: inches or		
				Dia. in. to ft. depth gage No. 1258		
				10. Screen: Manufacturer's name		
				Type PVC Dia. 5 1/2		
				Slot/gauze 40 Length 10		
				Set between 76 ft. and 86 ft.		
				Gravel pack? X Size range of material 4-30		
				11. Static water level: mo./day/yr.		
				60 ft. below land surface Date 5-24-76		
				12. Pumping level below land surfaces:		
				ft. after hrs. pumping g.p.m.		
				ft. after hrs. pumping g.p.m.		
				Estimated maximum yield g.p.m.		
				13. Water sample submitted: mo./day/yr.		
				Yes X No Date		
				14. Well head completion:		
				X Pitless adapter inches above grade		
				15. Well grouted? X		
				With: Neat cement Bentonite X Concrete		
				Depth: From 3 ft. to 13 ft.		
				16. Nearest source of possible contamination: OUTFALL		
				ft. 100 Direction SE Type Barn		
				Well disinfected upon completion? X Yes No		
				17. Pump: X Not installed		
				Manufacturer's name		
				Model number HP Volts		
				Length of drop pipe ft. capacity g.p.m.		
				Type:		
				Submersible Turbine		
				Jet Reciprocating		
				Centrifugal Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography:		Owner to run concrete		This well was drilled under my jurisdiction and this report		
Hill		slab around well, 4'x4'x4"		is true to the best of my knowledge and belief.		
Slope		Pump not installed by my		Backhus Drg. 180		
X Upland		company.		Business name License No.		
Valley				Address Tampa Ks.		
				Signed Paul Backhus Date		
				Authorized representative 6-16-76		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5