

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County McPherson	Fraction NE 1/4 NW 1/4	Section number 27	Township number T 20 S	Range number R 3 W
2. Distance and direction from nearest town or city: Street address of well location if in city:		1/2 mi. west of Elyria, 390 ft. south in field		3. Owner of well: R.R. or street: City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 6 in. Completion date 11-28-78 Well depth 74 ft.		
5. Type and color of material		From		To		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Top soil		0		3		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other
Gray clay		3		6		9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 18 lbs./ft. Dia. 3 in. to 54 ft. depth Wall thickness: inches or Dia. 3 in. to 54 ft. depth gage No. 216
Brown clay		6		18		10. Screen: Manufacturer's name Certain teed Type sawed Dia. 3 Slot/gauze 1/4 Length 20 Set between 34 ft. and 74 ft. ft. and ft. Gravel pack? yes Size range of material 1/8-1/4
Tan clay		18		36		11. Static water level: 42 ft. mo./day/yr. 42 ft. below land surface Date 11/28/78
Fine sand		36		38		12. Pumping level below land surfaces: 53 ft. after 1 hrs. pumping 12 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 12 g.p.m.
Tan clay		38		53		13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
Med. fine sand with clay		53		55		14. Well head completion: 18 inches above grade <input type="checkbox"/> Pitless adapter
Med. fine sand		55		69		15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
Shale		69		74		16. Nearest source of possible contamination: ft. Direction none Type <input checked="" type="checkbox"/> No Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
(Use a second sheet if needed)						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosenkrantz & Sons, Inc. Business name License No. 134 Address 1211 W. 4th Hutchinson, Kansas Signed Mike Flaws Date 6-18-79 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5