


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

| | | | | | | |
|---|--------------|---|--|--|----------------------------------|------------------------------|
| 1. Location of well: | | County McPHERSON | Fraction SE NW 1/4 SW 1/4 | Section number 31 | Township number T 20 S | Range number R 3 E |
| 2. Distance and direction from nearest town or city: 1 1/2 MI S S OF | | 3. Owner of well: GILBERT SCHRAG | | | | |
| Street address of well location if in city: McPHERSON, KS. | | R.R. or street: R.R. # 1 | | | | |
| | | City, state, zip code: McPHERSON, KS 67460 | | | | |
| 4. Locate with "X" in section below: | | Sketch map: | | | | |
|  | | | | | | |
| 5. Type and color of material | | From | To | 6. Bore hole dia. 30 in. Completion date 8-28-78 Well depth 235 ft. | | |
| Top Soil | | 0 | 5 | 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary | | |
| Buff Clay | | 5 | 27 | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other | | |
| Brown Clay | | 27 | 50 | 9. Casing: Material TRANSITE Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 32 lbs./ft. Dia. 16 in. to 16 1/2 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 34" | | |
| Brown Sandy Clay | | 50 | 62 | 10. Screen: Manufacturer's name AURORA TILE COMPANY Type TRANSITE Dia. 16 1/2 in. Slot/gauze 1/8 Length 65 Set between 16 1/2 ft. and 235 ft. ft. and <input type="checkbox"/> ft. | | |
| MEDIUM SAND | | 62 | 90 | Gravel pack? YES Size range of material 1/4 in | | |
| Gray Clay | | 90 | 102 | 11. Static water level: <input type="checkbox"/> mo./day/yr. 52 ft. below land surface Date 8-28-78 | | |
| MEDIUM SANDS | | 102 | 124 | 12. Pumping level below land surfaces: <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m. | | |
| Brown Clay | | 124 | 127 | 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> | | |
| Be MEDIUM COURSE SAND | | 127 | 130 | 14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade | | |
| Gray Clay | | 130 | 160 | 15. Well grouted? PURPLE CLAY With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft. | | |
| Brown Sandy Clay | | 160 | 178 | 16. Nearest source of possible contamination: ft. 500 Direction SW E Type CATTLE Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No | | |
| FINE SAND | | 178 | 192 | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other | | |
| MEDIUM COURSE SAND | | 192 | 201 | | | |
| Brown Clay | | 201 | 204 | | | |
| MEDIUM COURSE SAND | | 204 | 207 | | | |
| MEDIUM SAND (Use a second sheet if needed) | | 207 | 235 | | | |
| 18. Elevation: | 19. Remarks: | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. PETERSON IRRIGATION 138 Business name Box 150 KINGSBORG, KS License No. <input type="checkbox"/> Address Box 150 KINGSBORG, KS Signed Mike Peterson Date 9-25-78 Authorized representative | | | |
| Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley | | | | | | |

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5