

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

DTSD

1. Location of well:		County <b>SCOTT</b>	Fraction <b>SE 1/4 NW 1/4 SE 1/4</b>	Section number <b>30</b>	Township number T <b>20</b> S R	Range number <b>32</b> <span style="float:right">NW</span>																				
2. Distance and direction from nearest town or city: <b>North of Garden City on Hwy 83 to the County Line, 1 North, Street address of well location if in city: 3/4 East, 1/4 North.</b>				3. Owner of well: <b>Fairleigh Corporation</b> R.R. or street: City, state, zip code: <b>Scott City, Kansas 67871</b>																						
4. Locate with "X" in section below: <span style="float:right">Sketch map:</span>				6. Bore hole dia. <b>26</b> in. Completion date <b>8-6-75</b> Well depth <b>190</b> ft.																						
<div style="text-align: center;"> <p>N</p> <p>W</p> <p>S</p> <p>E</p> </div>				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary																						
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other																						
5. Type and color of material				9. Casing: Material <b>Steel</b> Height: Above <del>surface</del> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>36.87</b> lbs./ft. Dia. <b>16</b> in. to <b>191</b> ft. depth; Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth; gage No. <b>219</b>																						
<table border="1" style="width:100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 50%;">From</th> <th style="width: 50%;">To</th> </tr> </thead> <tbody> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> <tr><td> </td><td> </td></tr> </tbody> </table>				From	To																			10. Screens: Manufacturer's name <b>Johnson Division</b> Type <b>Galvanized</b> Dia. <b>16"</b> Slot/gauze <input type="checkbox"/> Length <b>20'</b> Set between <b>110</b> ft. and <b>180</b> ft. Perf: <b>100-110</b> ft. and <b>180-190</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>1/2" down</b>		
				From	To																					
11. Static water level: <span style="float:right">mo./day/yr.</span> <b>66</b> ft. below land surface Date <b>7-8-75</b>																										
12. Pumping level below land surfaces: <b>93</b> ft. after <b>2</b> hrs. pumping <b>857</b> g.p.m. <b>106</b> ft. after <b>4</b> hrs. pumping <b>1297</b> g.p.m. Estimated maximum yield _____ g.p.m.																										
13. Water sample submitted: <span style="float:right">mo./day/yr.</span> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____																										
14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade																										
15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.																										
16. Nearest source of possible contamination: ft. _____ Direction _____ Type <b>N/A</b> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No																										
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other																										
(Use a second sheet if needed)																										
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling 208</b> Business name License No. Address <b>Box A, Garden City, KS</b> Signed <i>[Signature]</i> Date <i>[Date]</i> Authorized representative																						
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley																										

20 320 30 SENEUSE  
 T  
R  
Sec  
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

**WILSON DRILLING CO.**  
INCORPORATED

and Borehole  
Water Systems  
Complete Installation  
and Repairing

Phone 236-6765 P.O. Box 493 • GARDEN CITY, KANSAS 67846

FAIRLEIGH FEEDS, INC.  
Scott County  
5-17-75

Location: Offset of pivot south 600 feet SE<sub>4</sub> 30-20-32

Test # 2

0	3	Top soil
3	10	Brown sandy clay
10	23	Fine to med. sand and gravel (loose)
23	28	Brown sandy clay
28	54	Fine to med. sand and gravel (loose)
54	76	Brown sandy clay
76	96	Brown gray clay, sand streak
96	110	White clay, rock (hard)
110	118	White rock (loose) Drill (loose)
118	124	Brown sandy clay
124	180	Fine to med. sand and gravel (loose)
180	182	Yellow clay
182	185	Shale

Strata ...