

1 LOCATION OF WATER WELL	Fraction	Section Number	Township Number	Range Number
County: <b>Scott</b>	<b>NE 1/4 NE 1/4 NW 1/4</b>	<b>2</b>	<b>T 20 S</b>	<b>R 33 EW</b>

Distance and direction from nearest town or city? **1 1/2 miles South**  
**1 3/4 West of Shallow Water, Kansas**

Street address of well if located within city?

2 WATER WELL OWNER: **Ted Patton**  
 RR#, St. Address, Box # :  
 City, State, ZIP Code : **Scott City, Kansas 67871**

Board of Agriculture, Division of Water Resources  
 Application Number:

3 DEPTH OF COMPLETED WELL... **160** ft. Bore Hole Diameter... **9** in. to **160** ft., and ... in. to ... ft.

Well Water to be used as:

<input checked="" type="checkbox"/> 1 Domestic	<input type="checkbox"/> 3 Feedlot	<input type="checkbox"/> 6 Oil field water supply	<input type="checkbox"/> 8 Air conditioning	<input type="checkbox"/> 11 Injection well
<input type="checkbox"/> 2 Irrigation	<input type="checkbox"/> 4 Industrial	<input type="checkbox"/> 7 Lawn and garden only	<input type="checkbox"/> 9 Dewatering	<input type="checkbox"/> 12 Other (Specify below)
<input type="checkbox"/> 10 Observation well				

Well's static water level ... **102** ft. below land surface measured on ... **4** month ... **27** day **1981** year

Pump Test Data : Well water was ... **120** ft. after ... **4** hours pumping ... **15** gpm

Est. Yield **30** gpm: Well water was ... ft. after ... hours pumping ... gpm

4 TYPE OF BLANK CASING USED:

<input checked="" type="checkbox"/> 1 Steel	<input type="checkbox"/> 3 RMP (SR)	<input type="checkbox"/> 6 Asbestos-Cement	<input type="checkbox"/> 8 Concrete tile	<input type="checkbox"/> 9 Other (specify below)
<input checked="" type="checkbox"/> 2 PVC	<input type="checkbox"/> 4 ABS	<input type="checkbox"/> 7 Fiberglass	Casing Joints: <input checked="" type="checkbox"/> Glued <input type="checkbox"/> Clamped <input type="checkbox"/> Welded <input type="checkbox"/> Threaded	

Blank casing dia ... **5** in. to **140** ft., Dia ... in. to ... ft., Dia ... in. to ... ft.

Casing height above land surface ... **12** in., weight **2.368** lbs./ft. Wall thickness or gauge No ... **.214**

TYPE OF SCREEN OR PERFORATION MATERIAL:

<input type="checkbox"/> 1 Steel	<input type="checkbox"/> 3 Stainless steel	<input type="checkbox"/> 5 Fiberglass	<input checked="" type="checkbox"/> 7 PVC	<input type="checkbox"/> 10 Asbestos-cement
<input type="checkbox"/> 2 Brass	<input type="checkbox"/> 4 Galvanized steel	<input type="checkbox"/> 6 Concrete tile	<input type="checkbox"/> 8 RMP (SR)	<input type="checkbox"/> 11 Other (specify)
Screen or Perforation Openings Are:			<input checked="" type="checkbox"/> 8 Saw cut	<input type="checkbox"/> 11 None (open hole)
<input type="checkbox"/> 1 Continuous slot	<input type="checkbox"/> 3 Mill slot	<input type="checkbox"/> 6 Wire wrapped	9 Drilled holes	
<input type="checkbox"/> 2 Louvered shutter	<input type="checkbox"/> 4 Key punched	<input type="checkbox"/> 7 Torch cut	10 Other (specify)	

Screen-Perforation Dia ... **5** in. to **160** ft., Dia ... in. to ... ft., Dia ... in. to ... ft.

Screen-Perforated Intervals: From ... **140** ft. to **160** ft., From ... ft. to ... ft., From ... ft. to ... ft.

Gravel Pack Intervals: From ... **100** ft. to **160** ft., From ... ft. to ... ft., From ... ft. to ... ft.

5 GROUT MATERIAL:  1 Neat cement  2 Cement grout  3 Bentonite  4 Other **Drill Cuttings**

Grouted Intervals: From ... **15** ft. to **100** ft., From ... **4** ft. to **15** ft., From ... ft. to ... ft.

What is the nearest source of possible contamination:

<input checked="" type="checkbox"/> 1 Septic tank	<input type="checkbox"/> 4 Cess pool	<input type="checkbox"/> 7 Sewage lagoon	<input type="checkbox"/> 10 Fuel storage	<input type="checkbox"/> 14 Abandoned water well
<input type="checkbox"/> 2 Sewer lines	<input type="checkbox"/> 5 Seepage pit	<input type="checkbox"/> 8 Feed yard	<input type="checkbox"/> 11 Fertilizer storage	<input type="checkbox"/> 15 Oil well/Gas well
<input type="checkbox"/> 3 Lateral lines	<input type="checkbox"/> 6 Pit privy	<input type="checkbox"/> 9 Livestock pens	<input type="checkbox"/> 12 Insecticide storage	<input type="checkbox"/> 16 Other (specify below)
Direction from well ... <b>Southeast</b> How many feet ... <b>200</b> ?			Water Well Disinfected? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	

Was a chemical/bacteriological sample submitted to Department? Yes  No  If yes, date sample was submitted ... month ... day ... year: Pump Installed?  Yes  No

If Yes: Pump Manufacturer's name ... **Red Jacket** Model No. **75NI9BB** HP **3/4** Volts **230**

Depth of Pump Intake ... **150** ft. Pumps Capacity rated at ... **10** gal./min.

Type of pump:  1 Submersible  2 Turbine  3 Jet  4 Centrifugal  5 Reciprocating  6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was  (1) constructed,  (2) reconstructed, or  (3) plugged under my jurisdiction and was completed on ... **4** month ... **28** day ... **1981** year and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. **232**

This Water Well Record was completed on ... **4** month ... **29** day ... **1981** year under the business name of **Weishaar Drilling & Supply Inc.** by (signature) *[Signature]*

LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:	FROM			TO			LITHOLOGIC LOG		
	FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG			
	0	29	Clay	29	37	Fine sand			
	37	41	Sand	41	47	Clay			
	47	57	Sand	57	97	Clay			
	97	106	Sand	106	117	Clay			
	117	155	Fine sand	155	160	Yellow clay			

ELEVATION:

Depth(s) Groundwater Encountered 1... **102** ft. 2... ft. 3... ft. 4... ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.

OFFICE USE ONLY

T 30

R 33

EAD

SEC. 2

NW 1/4

NE 1/4

SW 1/4

SE 1/4