

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County SCOTT	Fraction SE 1/4 NW 1/4 SE 1/4	Section number 10	Township number T 20 S R 33	Range number W
2. Distance and direction from nearest town or city: South og Scott City 1/2 North, 2 1/2 West Street address of well location if in city:			3. Owner of well: Alfred Crist R.R. or street: RFD 2 City, state, zip code: Scott City, Ks. 67871		
4. Locate with "X" in section below:		Sketch map:			
		6. Bore hole dia. <u>26</u> in. Completion date <u>1-12-75</u> Well depth <u>157</u> ft.			
		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>158</u> depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <u>219</u>			
		10. Screen Manufacturer's name: <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20'</u> Set between <u>127</u> ft. and <u>147</u> ft. Perf. <u>120-27</u> ft. and <u>147-157</u> ft. Gravel pack? <input checked="" type="checkbox"/> Yes See range of material <u>1/2" Down</u>			
		11. Static water level: _____ mo./day/yr. <u>106</u> ft. below land surface Date <u>1-10-76</u>			
		12. Pumping level below land surfaces: <u>136</u> ft. after <u>2</u> hrs. pumping <u>225</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.			
		13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____			
		14. Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter _____ Inches above grade			
		15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to <u>10</u> ft. N/A			
		16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
		17. Pump: _____ Not installed Manufacturer's name <u>Goulds US Pumps</u> Model number <u>UH66M34</u> HP <u>1 3/4</u> volts _____ Length of drop pipe <u>170</u> ft. capacity <u>200</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks: Surges after 136"				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Winter Wilson Drilling 208</u> Business name <u>P.O. Box A, Garden City, Ks.</u> License No. _____ Address _____ Signed <u>[Signature]</u> Date <u>1-30-76</u> Authorized representative				

20 330 10 SE NUSE
 Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

WINTER-WILSON DRILLING CO. INCORPORATED
Irrigation and Domestic Water Systems Complete Installation and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Alfred Crist
Scott County
11-26-75

Location: SE 10-20-33
First road North of Refinery, 2 1/2 West, 1/2 North,
50 feet East of road.

Static Water Level - 90

Test # 1

0	2	Top Soil
2	23	Brown Clay
23	37	Brown Sandy Clay
37	61	Fine to Med. Sand & Fine Gravel
61	80	Brown Clay
80	94	Fine to Med. Sand & Gravel
94	123	Brown Clay & White Rock
123	147	Fine to Med. Sand & Gravel
147	167	Yellow Clay
167	170	Shale