

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

DCB

1. Location of well:		County Scott	Fraction N/W 1/4 S/W 1/4 S/E 1/4	Section number 12	Township number T 20 S R 33 #W	Range number
2. Distance and direction from nearest town or city: 10 S 1/2 W of Scott City, Kansas Street address of well location if in city:			3. Owner of well: Paul Winderlin R.R. or street: rfd # 2 City, state, zip code: Scott City, Kansas 67871			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>9</u> in. Completion date <u>4/15/1978</u> Well depth <u>165</u> ft.	
		<p>feed lot X ----- 1300' ----- X well</p>			7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Clay sandy		0		65		9. Casing: Material <u>Plastic</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Glue Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>135</u> ft. depth Wall Thickness: inches or Dia. <u> </u> in. to <u> </u> ft. depth gage No. <u>.250</u>
Clay		65		99		10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16"</u> Length <u>30"</u> Set between <u>135</u> ft. and <u>165</u> ft. <u> </u> ft. and <u> </u> ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material <u>1/4X1/8"</u>
Fine sand clay		99		102		11. Static water level: <u>102</u> ft. below land surface Date <u>4/12/78</u> mo./day/yr.
Sand coarse		102		116		12. Pumping level below land surfaces: <u>124</u> ft. after <u>2</u> hrs. pumping <u>18</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u>18</u> g.p.m.
Clay		116		124		13. Water sample submitted: <u> </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>
Fine sand clay		124		130		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
Gyp & clay		130		137		15. Well grouted? <input checked="" type="checkbox"/> yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>15</u> ft.
Sand coarse		137		140		16. Nearest source of possible contamination: ft. <u>1300</u> Direction <u>W</u> Type <u>Feed Lot</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Fine sand good		140		157		17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Red Jacket</u> Model number <u>N14CC</u> HP <u>2</u> Volts <u>230</u> Length of drop pipe <u>160</u> ft. capacity <u>18</u> g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
Clay		157		168		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling & Sup. 232 Business name License No. Address <u>Scott City, KS 67871</u> Signature <u>[Signature]</u> Date <u>4/18/78</u> Authorized representative
Clay yellow		168		182		
Shale		182				
18. Elevation:		19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<i>Brock 168</i> <i>102</i> <i>66' sand above</i>				

T
R
E
S
S
E
C
1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5