

County: Scott Fraction SE Sec. 13 T 20 S R 33 E(W)

CORRECTION(S) TO WATER WELL COMPLETION RECORD (WWC-5)  
(to rectify lacking or incorrect information)

Owner: E-Z Serve, Inc.

Location was listed as:

Section-Township-Range: 15-20 S-33

Fraction (1/4 1/4 1/4): SE

Location changed to:

13-20 S-33 W

SE

Other changes: Initial statements: 4 South of Shallow Water, 2 1/4 West,  
1/4 North.

Changed to: From Shallow Water: 3 3/4 mi. S, 1/4 mi. W.

Comments: \_\_\_\_\_

Verification method: Note on USGS copy of WWC-5 from Keith Lebbin (former  
manager of GMD 1), other wells for same owner at same location,  
county ownership map, mapping tool on KGS website. initials: DRK date: 4/22/2015

Submitted by: Kansas Geological Survey, Data Resources Library, 1930 Constant Ave., Lawrence, KS 66047-3726  
to: Kansas Dept of Health & Environment, Bureau of Water, 1000 SW Jackson, Suite 420, Topeka, KS 66612-1367.

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Scott County</b>	Fraction 1/4 1/4 <b>SE</b> 1/4	Section number <b>15</b>	Township number T <b>20</b> S	R <b>33</b>	E/W
2. Distance and direction from nearest town or city: <b>4 South of Shallow Water, 2 1/2 West, 1/4 North</b> Street address of well location in city:				3. Owner of well: <b>E-Z Serve, Inc.</b> R.R. or street: <b>RFD 2</b> City, state, zip code: <b>Scott City, KS 67871</b>			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>4-29-79</b> Well depth <b>190</b> ft.			
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material		From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
				9. Casing: Material <b>Steel</b> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>1 ft.</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>33.38</b> lbs./ft. Dia. <b>16</b> in. to <b>190</b> ft. depth   Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth   gage No. <b>.250</b>			
				10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Johnson Galv. 100-10 3/4 to 16"</b> Slot/gouze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? <b>yes</b> Size range of material <b>1/4 to 5/8</b>			
				11. Static water level: _____ mg./day/yr. <b>90</b> ft. below land surface Date <b>1-26-79</b>			
				12. Pumping level below land surfaces: <b>160</b> ft. after <b>2</b> hrs. pumping <b>425</b> g.p.m. <b>160</b> ft. after <b>4</b> hrs. pumping <b>450</b> g.p.m. Estimated maximum yield <b>425</b> g.p.m.			
				13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____			
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ Inches above grade			
				15. Well grouted? <b>yes</b> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.			
				16. Nearest source of possible contamination: ft. _____ Direction <b>N/A</b> Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No			
				17. Pump: Not installed Manufacturer's name <b>Could 5 stg. 6" JHC Bowl</b> Model number <b>Elec. Motor 20</b> Volts _____ Length of drop pipe <b>180</b> ft. capacity <b>350</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
		(Use a second sheet if needed)					
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter Wilson Drilling Co. 208</b> 1/4 SE Business name License No. _____ Address <b>Box A, Garden City, KS 67846</b> Signed <i>[Signature]</i> Date <b>8-17-79</b> 1/4 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley							

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Phone 276-8269

P.O. Box A - GARDEN CITY, KANSAS 67846  
January 26, 1979

E-Z Serve Inc.  
Scott County

Location: S. E.  $\frac{1}{4}$  15-20-33 North end of Refinery  
Static Water Level - 85  
Test #

0	1	Top Soil
1	35	Brown Clay
35	41	Brown Clay and Sand
41	81	Brown Clay
81	96	Fine to med. sand and gravel (loose)
96	129	Brown Clay & White Rock (tight) (hard streaks)
129	140	Fine to med. sand and gravel (loose)
140	147	Fine to med. sand and gravel 30% Clay (loose)
147	155	Fine to med. sand and gravel (loose)
155	170	Fine to med. sand and fine gravel 10% Clay (loose)
170	187	Fine to med. sand and gravel (loose)
187	193	Yellow Clay (tight)
193	200	Shale (tight)