

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction G-SE^{1/4} 1/4 1/4	Section number 17	Township number T 20 S R 33	Range number E/W
2. Distance and direction from nearest town or city: 1 1/2 mi. South & 4 Mi. West of Scott City			3. Owner of well: Roy Brandenburg & Quincey Wheeler (Tenant) R.R. or street: Box 666 City, state, zip code: Van Horn, Tex. 79855			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 1/19/76 Well depth 161 ft.		
		<p style="text-align: center;">center of SE 1/4</p>		7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
5. Type and color of material		From	To	9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 20 lbs./ft. Dia. 16 in. to 161 ft. depth Wall Thickness inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219		
clay		0	60	10. Screen: Manufacturer's name Lakewood Type Millslot Dia. 16 Slot/gauze 1/8 Length 2" Set between 101 ft. and 161 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft.		
gyp		60	80	Gravel pack? yes Size range of material 1/2 x 5/8		
clay, sand		80	100	11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date 1/10/76		
cleansand, gravel 42		100	150	12. Pumping level below land surfaces: 100 ft. after 6 hrs. pumping 500 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 500 g.p.m.		
clay, shale		150	160	13. Water sample submitted: _____ mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date _____		
				14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: _____ ft. _____ Direction _____ Type NA Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: _____ Not installed Manufacturer's name Workington Model number 28-12L-5HP _____ Volts _____ Length of drop pipe 140 ft. capacity 540 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				(Use a second sheet if needed)		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc. 136 Business name _____ License No. _____ Address 102 N 3rd, Garden City, Ks. Signed Wladimir Markov Date 2-4-76 Authorized representative			
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland LEVEL <input type="checkbox"/> Valley						

22
 33
 17
 CSE
 1/4
 1/4
 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5