

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.


# SHALLOW WATER

2033 W 23 CCB  
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

CBC

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County <b>Scott</b>	Township name	Fraction <b>SW, NW, SW</b>	Section number <b>23</b>	Town number <b>T 20 S</b>	Range number <b>R 33 W</b>
Distance and direction from nearest town or city: <b>Approx. S.S. &amp; 2 W. From</b> Street address of well location if in city: <b>Shallow Water</b>				3 Owner of well: <b>Albert Savolt</b> Address: <b>2120 Buffalo Heights Garden City, Mo</b>		
Locate with "X" in section below: N  W E S 1 Mile				4 Well depth: <b>165</b> ft. Date of completion _____ Well diameter <b>28</b> in. <b>28 May 75</b>		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Well drilled near site of TH 3-74 (see attached), which is 713' N. of SW cor of SW 1/4, Sec 23, 20-33, Scott Co.				7 Casing: Material <b>steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. Diam. <b>16</b> in. to <b>165</b> ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
				8 Screen: Manufacturer <b>Cook &amp; Doerr</b> Type <b>WW &amp; Doerr</b> Dia. <b>16"</b> Slot/gauze <b>1/8"</b> Length <b>50'</b> Set between <b>115</b> ft. and <b>165</b> ft. Fittings: <b>1-9 mm</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material _____		
BROCK 165'				9 Static water level: <b>87</b> ft. below land surface Date <b>12 Feb 75</b>		
				10 Pumping level below land surfaces: <b>123</b> ft. after <b>1</b> hrs. pumping <b>1800</b> g.p.m. <b>120</b> ft. after <b>1</b> hrs. pumping <b>2050</b> g.p.m. Estimated maximum yield <b>2050</b> g.p.m.		
(use a second sheet if needed)				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Depth: From <b>0</b> ft. to <b>10</b> ft.		
				14 Nearest source of possible contamination: <b>LNK</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Layne</b> Model number <b>1276</b> HP <b>30</b> Volts _____ Length of drop pipe <b>150</b> ft. capacity <b>1500</b> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
				16 Remarks: elevation <b>2937 (TOPO)</b>		
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Layne-Western Co 150</b> Business name License No. _____ Address <b>Garden City</b> Signed <b>[Signature]</b> Date <b>14 May 75</b> Authorized representative						

