

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

1. Location of well:		County Scott	Fraction S/W 1/4 S/W 1/4 S/W 1/4	Section number 33	Township number T 20 S R 33	Range number #W		
2. Distance and direction from nearest town or city: 1/4 N., 3 1/2 W. of Friend, #### Street address of well location if in city: Kansas			3. Owner of well: Delbert Campbell R.R. or street: Holcomb, Kansas 67851 City, state, zip code:					
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile			Sketch map: Ceptic tank X 150' X well		6. Bore hole dia. <u>9</u> in. Completion date _____ Well depth <u>115</u> ft. <u>10-26-1977</u>			
5. Type and color of material			From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			Clay		0	59	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
			Gyp		59	72	9. Casing: Material <u>Plastic</u> Weight: Above or below Threading <u>glue</u> Surface <u>12</u> in. RMP <input checked="" type="checkbox"/> PVC _____ Weight <u>1.8</u> lbs./ft. Dia. <u>5</u> in. to <u>85</u> ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. <u>250</u>	
			Clay		72	77	10. Screen: Manufacturer's name <u>Jess & Lowell</u> Type <u>RMP</u> Dia. <u>5"</u> Slot/gauze <u>1/16"</u> Length <u>30'</u> Set between <u>85</u> ft. and <u>115</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>1/4-1/8"</u>	
			Sandy clay ##		77	82	11. Static water level: _____ mo./day/yr. <u>76</u> ft. below land surface Date <u>10-26-77</u>	
			clay		82	90	12. Pumping level below land surfaces: <u>NA</u> _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
			Fine sand Clay		90	101	13. Water sample submitted: _____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
			sand rock		101	105	14. Well head completion: <u>NA</u> <input type="checkbox"/> Pitless adapter _____ Inches above grade	
			Sand fine		105	107	<input checked="" type="checkbox"/> Well grouted? <u> </u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>4</u> ft. to <u>1.5</u> ft.	
			Sand rock		107	109	16. Nearest source of possible contamination: ft. <u>150</u> Direction <u>N/E</u> Type <u>Septic</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Clay yellow		109	115	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other				
(Use a second sheet if needed)								
18. Elevation:		19. Remarks: Customer finishing well & setting pump.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Weishaar Drilling 232 Business name _____ License No. _____ Address <u>Scott City, Ks. 67871</u> Signed <u>[Signature]</u> Date <u>10-27-77</u> Authorized representative				

T
R
S
S
S
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5