


USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

MODOC SE

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CAF

1. Location of well:		County Scott	Fraction NE 1/4 NE 1/4 SW 1/4	Section number 15	Township number T 20 S	Range number R 34 E 1/4
2. Distance and direction from nearest town or city: Street address of well location if in city: 8 1/2 W, 4 1/2 S of shallow water			3. Owner of well: Barclay Minnick Berl Minnix R.R. or street: City, state, zip code: Modoc, Kansas 67866			
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 1 5/8 Completion date 4-27-77 Well depth 150 ft.			
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Plastic pipe Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 24 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 8 in. to 11 1/2 ft. depth Wall Thickness: inches of Dia. _____ in. to _____ ft. depth gage No. Sch 40 M&C			
			10. Screen: Manufacturer's name Jesse Lowell Type Plastic Dia. 8 Slot/gauze 1/16 Length 50 Set between 99 ft. and 149 ft. ft. and _____ ft. Gravel pack? Yes Size range of material 3/16			
			11. Static water level: _____ mo./day/yr. 112 ft. below land surface Date 4-28-77			
			12. Pumping level below land surfaces: 115 ft. after 2 hrs. pumping 50 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 50 g.p.m.			
			13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 24 Inches above grade			
			15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 3 ft. to 15 ft.			
			16. Nearest source of possible contamination: ft. _____ Direction None Type Field Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>			
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Pump Co Model number P703034 HP 3 Volts 110 Length of drop pipe 147 ft. capacity 50 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply, Inc. 136A Business name Garden City, NKS Address 402 N 3rd 6-27-77 Signed Arthur B. Dickerson Date _____ Authorized representative			
19. Remarks: 3060						

20 34 E 1 S NE NE SW 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5