

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Wichita	Fraction SE 1/4 SE 1/4 SW 1/4	Section number 23	Township number T 20 S R 36 E/W	Range number 36
2. Distance and direction from nearest town or city: 14 so. 4 east 1 no. (Leoti) Street address of well location if in city:			3. Owner of well: Heye Wilken R.R. or street: Rte # 2 City, state, zip code: Leoti, Kansas 67861		
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 2 3/4 in. Completion date 10/4/78 Well depth 154 ft.	
5. Type and color of material		From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Clay		0	20	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Clay - gyp		20	40	9. Casing: Material pltc Height: Above or below Threading <input type="checkbox"/> Welded glu Surface 24 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 154 ft. depth; Wall Thickness: inches or Dia. _____ in. to _____ ft. depth; gage No. sch. 40	
Med. sand		40	100	10. Screen: Manufacturer's name Jesse Lowell Type PVC Dia. 5" Slot/gauze 1/16 Length 20' Set between 134 ft. and 154 ft. _____ ft. and _____ ft. Gravel pack? yes Size range of material 3/16	
Med. sand		100	115	11. Static water level: _____ mo./day/yr. 103 ft. below land surface Date 10/2/78	
Clay		115	130	12. Pumping level below land surfaces: 115 ft. after 2 hrs. pumping 10 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 10 g.p.m.	
				13. Water sample submitted: _____ mo./day/yr. ### Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____	
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 24 inches above grade	
				15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 14 ft. to 3 ft.	
				16. Nearest source of possible contamination: none ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name owners pump Model number _____ HP 1 1/2 Volts 230 Length of drop pipe 147 ft. capacity _____ g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. High Plains Drilling & Supply Business name _____ License No. 136 Address 5310 W. Hwy 50 Garden City KS Signed Arthur R. Kuhlman Date _____ Authorized representative	
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

20
36
23
SESESW
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5