

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


SECKIRK SE

WATER WELL RECORD
KSA 82a-1201-1215

4AD

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Wichita	Township name Whitewoman	Fraction SE-NE $\frac{1}{4}$ of NE $\frac{1}{4}$	Section number 8	Town number 20 S	Range number 38 W
Distance and direction from nearest town or city: $\frac{1}{2}$ mi. east, 9 mi. south, $\frac{1}{2}$ mi. west & $\frac{1}{4}$ mi. south of				3 Owner of well: Dave Woelk		
Street address of well location if in city: Selkerk				Address: Tribune, Kansas 67879		
Locate with "X" in section below: 				4 Well depth: 220 ft. Date of completion 3/4/75 Well diameter 26 in.		
2 Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
Overburden				7 Casing: Material steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. Weight lbs./ft. 16 in. to 220 ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth		
				8 Screen: W. A. Brown Manufacturer Free Flo Dia. 16 Type slot Length 2" Set between 180 ft. and 220 ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 5/8		
Sand & a little clay				9 Static water level: 170 ft. below land surface Date 3/8/75		
Shale				10 Pumping level below land surfaces: 210 ft. after 6 hrs. pumping 450 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 450 g.p.m.		
BROCK 214'				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: ft. Direction Type None Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(use a second sheet if needed)						
16 Remarks: elevation Level 3429 (top)				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. ARK VALLEY PUMP & SUPPLY 123 Business name License No. Address 205 S. First Signed Dave Smith Date 8/30/75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5