


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction nw 1/4 nw 1/4 ne 1/4	Section number 2	Township number T 20 S R 4 E/W	Range number
2. Distance and direction from nearest town or city: 3-W 1-S of McPherson, Ks. Street address of well location if in city:			3. Owner of well: H-30 Drilling Co. R.R. or street: 200 N. Main City, state, zip code: Wichita, Ks. 67202		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 8 in. Completion date 3-28-75 Well depth 150 ft.
top soil			0	3	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
clay			3	72	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other
sand & gravel			72	90	9. Casing: Material pvc Height: Above 20 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 20 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 150 lbs./ft. Dia. 4 in. to 150 ft. depth Wall Thickness: inches or Dia. 4 in. to 150 ft. depth Gauge No. 237
clay			90	112	10. Screen: Manufacturer's name CertainTeed Type pvc Dia. 4 Slot 1/16 Length 40 Set between 110 ft. and 150 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 3/4 3/8
sand & gravel			112	150	11. Static water level: 60 ft. below land surface Date 3-28-75 12. Pumping level below land surfaces: 70 ft. after 1 hrs. pumping 100 g.p.m. 300 g.p.m. Estimated maximum yield 300 g.p.m.
					13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
					15. Well grouted? <input checked="" type="checkbox"/> With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: ft. 96 Direction east Type oilwell Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Rosencrantz-Bemis 134 Business name License No. Address Great Bend, Ks. 67530 Signed R. Kilgore Date 6-19-75 Authorized representative
18. Elevation: X Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks: valley				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WW-C-5