


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County McPherson	Township name Groveland	Fraction NE¹/₄ NE¹/₄ SW¹/₄	Section number 9	Town number 20S	Range number 4 - W
Distance and direction from nearest town or city: 2 Mi. South			3 Owner of well: Eldon Newfeldt			
Street address of well location if in city: 1/2 Mi. East Of Conway			Address: R 2 McPherson, Kansas			
Locate with "X" in section below: N  S 1 Mile			Sketch map:			4 Well depth: 97 ft. Date of completion 4-1 Well diameter 9 in.
2 Type and color of material			From	To	5 <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
Yellow Clay			0	21	6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>	
Red Shale			21	62	7 Casing: Plastic Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Class 160 in. Diam. 5 in. to 97 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!	
Some Water			62		8 Screen: Certain-teed Manufacturer _____ Type Plastic Dia. 5 1/8 in. Slot/gauze 1/8 in. Length 18 Set between 62 ft. and 90 ft. Fittings: _____ Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4 to 1/3	
Yellow Rock			62	65	9 Static water level: 40 ft. below land surface Date 4-1-75	
Red Shale			65	82	10 Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.	
Gray Shale			82	90	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
Water			90		12 Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
Red Shale			92	97	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 93 ft. to 13 ft.	
					14 Nearest source of possible contamination: ft. 1/2 Mi. Direction West Type Barnyard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)						
16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhus Drilling 180 Business name _____ License No. _____ Address Tampa, Kansas Signed John Backhus Date 4-1-75 Authorized representative			