


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Mpherson</b>	Fraction <b>1/4 NW 1/4 SW 1/4</b>	Section number <b>18</b>	Township number <b>20</b>	Range number <b>4</b>
2. Distance and direction from nearest town or city:		<b>4 1/2 W 1 1/4 N</b>		3. Owner of well: <b>Jim Fast</b>		
Street address of well location if in city:		<b>Groveland</b>		City, state, zip code: <b>Conway, Ks.</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>8 1/2</b> in. Completion date Well depth <b>80</b> ft. <b>6-6-78</b>		
				7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <b>PVC</b> Height: <b>12</b> ft. below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <b>5.5</b> lbs./ft. Dia. <b>5</b> in. to <b>80</b> ft. depth Wall Thickness: inches Dia. <b>5</b> in. to <b>80</b> ft. depth gage No. <b>258</b>		
				10. Screen: Manufacturer's name <b>ASTM</b> Type <b>PVC</b> Dia. <b>3-4</b> Slot/gauze <b>20</b> Length <b>20</b> Set between <b>55</b> ft. and <b>63</b> ft. <b>70</b> ft. and <b>80</b> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <b>4-10</b>		
				11. Static water level: <b>30</b> ft. below land surface Date <b>6-6-78</b>		
				12. Pumping level below land surfaces: ____ ft. after ____ hrs. pumping ____ g.p.m. ____ ft. after ____ hrs. pumping ____ g.p.m. Estimated maximum yield ____ g.p.m.		
				13. Water sample submitted: ____ mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date ____		
				14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter ____ Inches above grade <input checked="" type="checkbox"/> Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>13</b> ft.		
				16. Nearest source of possible contamination: ft. <b>75+</b> Direction <b>SE</b> Type <b>Legume</b> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name ____ Model number ____ HP ____ Volts ____ Length of drop pipe ____ ft. capacity ____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley		<b>Owner to run concrete slab around well 4'x4'x4"</b>		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Backhus Drilling</b> Business name <b>Jampa Ks</b> License No. ____ Address <b>Paul Backhus</b> Date <b>6-6-78</b> Signed <b>Paul Backhus</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5