

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County McPherson	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 27	Township number T 20 S	Range number R 4 E
2. Distance and direction from nearest town or city: Street address of well location if in city:	3 N 1 E Inman		3. Owner of well: howell sawyer R.R. or street: RR 2 City, state, zip code: McPherson 67460		
4. Locate with "X" in section below:	<p>Sketch map: House No Septic Tank Well Approx 200' Barn yard</p>		6. Bore hole dia. 8 1/2 in. Completion date 11-13-75 Well depth 85 ft.		
5. Type and color of material	From To		7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
top Soil	0	3	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
yellow clay	3	22	9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 15 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 160 lbs./ft. Dia. 5 in. to 85 ft. depth Wall Thickness: inches or Dia. 5 in. to 85 ft. depth gage No. 025		
Some water	22		10. Screen: Manufacturer's name Pumpco Supply Type PVC Dia. 5 in. Slot/gauze 70 Length 15 Set between 70 ft. and 85 ft. ft. and 85 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4		
yellow clay	22	30	11. Static water level: 35 ft. below land surface Date 11-13-75 mo./day/yr.		
Bed + yellow clay	30	75	12. Pumping level below land surfaces: ft. after 70 hrs. pumping 15 g.p.m. ft. after 75 hrs. pumping 15 g.p.m. Estimated maximum yield 15 g.p.m.		
water	75		13. Water sample submitted: well house Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 11-13-75 mo./day/yr.		
yellow shale	75	80	14. Well head completion: well house Pitless adapter 15 inches above grade		
Red shale	80	85	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: ft. 200 Direction East Type Barn yard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
18. Elevation:	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Backhus Drilling 180 Business name License No. _____ Address Topeka, Mo. Signed Paul Backhus Date 12-16-75 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5