

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Greeley	Fraction NW 1/4 NW 1/4 NW 1/4	Section number 24	Township number T 40 S R 40 W E/W	Range number
2. Distance and direction from nearest town or city: 11 mi. s. & 3 mi. E. of Tribune, Kansas Street address of well location if in city:			3. Owner of well: Sunflower Electric R.R. or street: City, state, zip code: Tribune, Kansas 67879			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. <u>7</u> in. Completion date <u>9-1-79</u> Well depth <u>210</u> ft.	
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input checked="" type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
					9. Casing: Material <u>steel</u> Height: <u>18 ABOVE</u> Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>18 ABOVE</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. <u>5</u> in. to <u>190</u> ft. depth Wall Thickness: _____ inches or Dia. _____ in. to _____ ft. depth gage No. <u>188</u>	
5. Type and color of material		From	To	10. Screen: Manufacturer's name _____ (Perf.) Type <u>Torch cut</u> Dia. <u>5 in.</u> Slot <u>xxx</u> Length <u>20 ft.</u> Set between <u>190</u> ft. and <u>210</u> ft. _____ ft. and _____ ft. Gravel pack? <u>yes</u> Size range of material <u>3/8"</u>		
Top soil & clay		0	30	11. Static water level: _____ mo./day/yr. <u>180</u> ft. below land surface Date <u>9-1-79</u>		
Clay		30	45	12. Pumping level below land surfaces: <u>209</u> ft. after <u>2</u> hrs. pumping <u>15</u> g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield <u>15</u> g.p.m.		
Clay & lime		45	70	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____		
Sand		70	120	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>18</u> inches above grade		
Clay		120	128	15. Well grouted? <u>yes</u> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>30</u> ft.		
Sand & Clay		128	152	16. Nearest source of possible contamination: <u>house</u> ft. <u>100</u> Direction <u>west</u> Type <u>well</u> Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Clay		152	180	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Sand		180	195			
Clay		195	199			
Sand		199	202			
Clay & Shale		(202)	210			
(Use a second sheet if needed)						
18. Elevation:		19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ark Valley Pump & Supply 123 Business name _____ license No. _____ Address <u>Box 235 Holly, Co. 810</u> Signed <u>[Signature]</u> Date <u>10-1-79</u> Authorized representative	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		<u>TOPO 3454</u>				

20
 40
 24
 Sec
 1/4
 NW
 1/4