WATER WELL RECORD KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

						<u>'</u>	T		
1 . I	County Fraction			Section number		Township number	Range number		
1. Location of well:	Rice	SW 1/4SW 1/4	SW 1/4	17		T 20 S	R 7	€ ⊘	
2. Distance and direc	3. 0	3. Owner of well: Cecil Miller, etal *							
					R.R. or street: Route 1				
Street address of well location if in city: City, state, zip code:						Lyons, KS 6	7554		
4. Locate with "X" in section below: Sketch map:						6. Bore hole dia5in	. Completion date 1-1:	<u>2–7</u> 8	
N						Well depth 58 ft.	-		
Test Well No. 27						7 Cable tool X Rotary Driven Dug			
					Hollow rod Jetted Bored Reverse rotary				
					8. Use: Domestic P				
					Irrigation Air conditioning Stock				
					LawnOil field water _XOther—Test Wel				
						9. Casing: Material PVC			
						Threaded Welded	ISurface	in.	
S						RMP PVC X	!Weight <u> </u>	s./ft.	
1← 1 Mile → I					Dia. $\frac{2\frac{1}{2}}{1}$ in. to $\frac{48}{1}$ ft. depth Wall Thickness: inches or Diain. to ft. depth gage No. $\frac{10}{10}$				
5. Type and color of	material			From	То				
		****			 	10. Screen: Manufacturer's	name <u>Claire</u>		
Top soil				0	3	Type PVC	$-$ Dig. $2\frac{1}{2}$!!		
				7	77	Slot gauze 1/8"	Length 10 !		
Brown &	gray clay			3	33	Set between48	_ft. and <u>58</u>	ft.	
0 10		-1		33	50	ft.	and 1 / / !!	—f†·	
Sand & g	ravel & clay strea	aks		133	1 50	Gravel pack? <u>Ves</u> Size r			
Sand & g	ravel			50	58	11. Static water level: 29.9 ft. below land so	mo./do		
				F0	60				
Red shal	e	· · · · · · · · · · · · · · · · · · ·		58	60	12. Pumping level below lar			
					1	ft. after	hrs. pumping g.	.p.m.	
					+	Estimated maximum yield —		1	
				İ	1	13. Water sample submitted:		ay/yr.	
						<u>X</u> Yes No	Date <u>1-12-78</u>		
						14. Well head completion:		i	
						Pitless adapter	Inches above gra	ide	
					+	15. Well grouted? NO		10,	
						With: Neat cement Depth: From ft. to		ocrete ¬!~	
	•								
					_	16. Nearest source of possible ft Direction			
						Well disinfected upon comp	. Y	_No	
				-	-	17. Pump:	X Not installed		
						Manufacturer's name		$- \tilde{l} $	
						Model number		1 17	
					-	Length of drop pipe	ft. capacityg	.p.m. 🐔	
						Type: Submersible	Turbine		
					+	Jet	Reciproca	ting L	
	(Use a second	d sheet if needed)				Centrifugal	Other	, & ,	
18. Elevation: 19. Remarks: * Work performed on ■ behalf of Cecil						20. Water well contractor's	certification:	\neg	
(Ground) Miller etal to obtain ground water information						This well was drilled under my jurisdiction and this report			
1651.9 RE: Miller vs. Cudahay lawsuit.						is true to the best of my knowledge and belief.			
** Test wells were considered temporary when						Clarke Well & Eq., Inc. 185			
<pre>"* Test wells were considered temporary when drilled. Due to pending litigations, a decision to plug wells or grout and establish permanent</pre>						MBusiness name Address Great Bend, KS 67530			
Slope	Observation wells has not been III made.						8-25-78		
Valley							Signed Authorized representative Date		