

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

| | | | | | |
|---|---|--|---|--------------------------------------|--|
| 1. Location of well: | County Rice | Fraction SW 1/4 SW 1/4 NW1/4 | Section number 29 | Township number T 20 S R 7 | Range number 7 |
| 2. Distance and direction from nearest town or city: 7 1/2 miles Southeast of Lyons, KS Street address of well location if in city: | | | 3. Owner of well: Cecil Miller, etal * R.R. or street: Route 1 City, state, zip code: Lyons, KS 67554 | | |
| 4. Locate with "X" in section below: N W E S 1 Mile | | | Sketch map: Test #22 2340 south & 90' East of NW corner of Sec. 29 | | |
| 5. Type and color of material | | | From | To | 6. Bore hole dia. 5 in. Completion date 1-5-78 Well depth 62 ft. |
| Top soil | | | 0 | 3 | 7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary |
| Brown & gray clay | | | 3 | 17 | 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other-Test Well |
| Sand & gravel & thin clay at 39' | | | 17 | 62 | 9. Casing: Material PVC Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <input type="checkbox"/> in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 631 lbs./ft. Dia. 2 1/2 in. to 52 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 110 |
| Red shale | | | 62 | 65 | 10. Screen: Manufacturer's name Clarke Type PVC Dia. 2 1/2" Slot gauze 1/8" Length 10' Set between 52 ft. and 62 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4" |
| | | | | | 11. Static water level: <input type="checkbox"/> mo./day/yr. 9.3 ft. below land surface Date 3-17-78 |
| | | | | | 12. Pumping level below land surfaces: Not Checked ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m. |
| | | | | | 13. Water sample submitted: chl-286 mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 1-5-78 |
| | | | | | 14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade |
| | | | | | 15. Well grouted? NO ** With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft. |
| | | | | | 16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No |
| | | | | | 17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other |
| (Use a second sheet if needed) | | | | | |
| 18. Elevation: (Ground) 1627.6 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley | 19. Remarks: * Work performed on behalf of Cecil Miller etal to obtain ground water information RE: Miller vs. Cudahay lawsuit. ** Test wells were considered temporary when drilled. Due to pending litigation, a decision to plug wells or grout & establish permanent observation wells has not been made. | | 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Eq., Inc. 185 Business name License No. Address Great Bend, KS 67530 Signed [Signature] Date 8-25-78 Authorized representative | | |

T
R
W
E
29
1/4
1/4
1/4
S
W
S
W
W
E
E