


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Rice	Fraction SW 1/4 NW 1/4 SE 1/4	Section number 10	Township number T 20 S R 8	Range number 8	EW	
2. Distance and direction from nearest town or city: 1 mile South of Lyons, KS. Street address of well location if in city:			3. Owner of well: Cecil Miller etal * R.R. or street: Route 1 City, state, zip code: Lyons, KS 67554				
4. Locate with "X" in section below: <div style="text-align: center;">  </div>			Sketch map: Test Well No. 3 2050'N & 2600'W - SE Cor. 10			6. Bore hole dia. 5 in. Completion date 12/12/77 Well depth 68 ft.	
5. Type and color of material			From	To	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other -Test Well		
					9. Casing: Material PVC Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 1.90' RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight .631 lbs./ft. Dia. 2 1/2 in. to 58 ft. depth Wall Thickness, inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. .110		
					10. Screen: Manufacturer's name Clarke		
					Type PVC Dia. 2 1/2" Slot/gauze 1/8" Length 10' Set between 58 ft. and 68 ft. <input type="checkbox"/> ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4" ft.		
					11. Static water level: <input type="checkbox"/> mo./day/yr. 14.5 ft. below land surface Date 3-17-78		
					12. Pumping level below land surfaces: NC <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
					13. Water sample submitted: chl. 2530 mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date 12/12/77		
					14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
					15. Well grouted? No ** With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.		
		16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No					
		17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)							
18. Elevation: (Ground) 1652.2 Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks: * Work performed on behalf of Cecil Miller etal to obtain ground water information RE: Miller vs. Cudahay Lawsuit. ** Test wells were considered temporary when drilled. Due to pending litigations, a decision to plug wells or grout & establish permanent observation wells has not been made.		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip., Inc. 185 Business name Great Bend, KS 67530 License No. Address 1/4 1/4 1/4 Signed [Signature] Date 8-25-78 Authorized representative			

B2 S W
 Sec 10 SW 1/4