

USE TYPEWRITER OR BALL POINT PEN—PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment—Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Rice	Fraction SW 1/4 SE 1/4 SW 1/4	Section number 11	Township number T 20 S R 8 E W	Range number
2. Distance and direction from nearest town or city: 1 1/4 mile south and 1 mile east of Lyons, Kansas.			3. Owner of well: Cecil Miller et al* R.R. or street: Route 1 City, state, zip code: Lyons, KS 67554		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: Test Well No. 8 1650'E & 30'N - SW Cor. 11		
5. Type and color of material			From	To	6. Bore hole dia. <u>5</u> in. Completion date <u>12/21/77</u> Well depth <u>67</u> ft.
Top Soil			0	3	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
Brown and Gray Clay			3	24	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input checked="" type="checkbox"/> Other— Test Well
Sand and Gravel			24	34	9. Casing: Material <u>PVC</u> Height: <u>Above</u> or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface <u>2.30'</u> RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <u>.631</u> lbs./ft. Dia. <u>2 1/2</u> in. to <u>57</u> ft. depth; Wall Thickness <u>inches</u> or Dia. <u>in.</u> to <u>ft.</u> depth; gage No. <u>.110</u>
Yellow Clay			34	36	10. Screen: Manufacturer's name <u>Clarke</u> Type <u>PVC</u> Dia. <u>2 1/2"</u> Slot/gauze <u>1/8"</u> Length <u>10"</u> Set between <u>57</u> ft. and <u>67</u> ft. ft. and <u>ft.</u> Gravel pack? <u>yes</u> Size range of material <u>1/4"</u>
Sand and Gravel			36	52	11. Static water level: <u>16.7</u> ft. below land surface Date <u>3-17-78</u> mo./day/yr.
Yellow Clay and Gravel			52	56	12. Pumping level below land surfaces: <u>NC</u> <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>g.p.m.</u>
Sand and Gravel			56	67	13. Water sample submitted: <u>Chl-4550</u> mo./day/yr. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Date <u>12/21/77</u>
Red Shale			67	70	14. Well head completion: <input type="checkbox"/> Pitless adapter <u>inches</u> above grade
					15. Well grouted? <u>No**</u> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>ft.</u> to <u>ft.</u>
					16. Nearest source of possible contamination: ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>Clarke Well & Equip., Inc.</u> Model number <u>HP</u> <u>Volts</u> Length of drop pipe <u>ft.</u> capacity <u>g.p.m.</u> Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Clarke Well & Equip., Inc. 185 Business name <u>Great Bend, KS 67530</u> License No. Address <u>8-25-77</u> Signed <u>[Signature]</u> Date <u>8-25-77</u> Authorized representative
18. Elevation: (Ground) <u>1648.1</u> Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			19. Remarks: * Work performed on behalf of Cecil Miller et al to obtain ground water information RE: Miller vs. Cudahay lawsuit. ** Test wells were considered temporary when drilled. Due to pending litigations, a decision to plug wells or <input checked="" type="checkbox"/> grout and establish permanent observation wells has not been made.		

20-8-11-1/4
 R-8-11-1/4
 Sec 11-1/4
 1/4 8/14
 SWSESW