USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

Photo

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Rcc

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Rice	SW 1/4 SW 1/4 NW 1/4	11	T 20 S	R 8 E/W

2. Distance and direction from nearest town or city:
1 mile south of Lyons, Ks.
Street address of well location if in city:

3. Owner of well:
R.R. or street: Northern Natural
Box 88
City, state, zip code: Lyons, Ks.

4. Locate with "X" in section below: Sketch map:

N
NW NE
W X E
SW SE
S
1 Mile
1 Mile

5. Type and color of material	From	To
Sandy top soil	0	6
Brown clay	6	22
Good sand and gravel	22	45
Yellow clay androck	45	50
Bedrock ≈ 50'		

(Use a second sheet if needed)

6. Bore hole dia. 11 in. Completion date
Well depth 50 ft. 9-29-76

7. __ Cable tool X Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored __ Reverse rotary

8. Use: X Domestic __ Public supply __ Industry
__ Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material
Threaded __ Welded X
RMP PVC X
Dia. 5½ in. to 46 ft. depth
Dia. in. to ft. depth
Height: Above or ~~below~~
Surface 18 in.
Weight 160 lbs./ft.
Wall Thickness: inches or gage No. 7

10. Screen: Manufacturer's name R & B
Type pvc Dia. 5½
Slot/~~gauze~~ slot 1/16 Length ~~5½~~ 15
Set between 31 ft. and 46 ft.
ft. and ft.
Gravel pack? X Size range of material 3/4-3/8=½

11. Static water level: mo./day/yr.
23 ft. below land surface Date 9-29-76

12. Pumping level below land surfaces:
27 ft. after 1 hrs. pumping 40 g.p.m.
ft. after hrs. pumping g.p.m.
Estimated maximum yield 100 g.p.m.

13. Water sample submitted: mo./day/yr.
X Yes __ No Date 9-27-76

14. Well head completion:
__ Pitless adapter __ Inches above grade

15. Well grouted? X
With: __ Neat cement __ Bentonite X Concrete
Depth: From 0 ft. to 10 ft.

16. Nearest source of possible contamination:
ft. 1000 Direction east Type gas well
Well disinfected upon completion? X Yes __ No

17. Pump: X Not installed
Manufacturer's name
Model number HP Volts
Length of drop pipe ft. capacity g.p.m.
Type:
__ Submersible __ Turbine
__ Jet __ Reciprocating
__ Centrifugal __ Other

20 T — 8 R — 17 Sec — SE 1/4 1/4 1/4

18. Elevation: 1655
Topography:
__ Hill
__ Slope
X Upland
__ Valley

19. Remarks: Topo map

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Rosencrantz-Bemis 134
Business name License No.
Address Great Bend, Ks.
Signed [signature] Date 10/1/76
Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5