

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

CBB

1 Location of well:		County Rice	Township name Atlanta NW 1/4 NW 1/4 SW 16-20	Fraction 20	Section number 20	Town number 8 W	Range number 8 W
Distance and direction from nearest town or city: 2 S. 1 W. 1/2 S			3 Owner of well: JAMES E. McALLESTER				
Street address of well location if in city: Lyon Mo.			Address: Lyon, Kans. RT				
Locate with "X" in section below:		Sketch map:			4 Well depth: 67 ft. Date of completion 10-11-76 Well diameter 8 in.		
					5 <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
					6 Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well <input type="checkbox"/>		
					7 Casing: Material PLTS Height: above below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. Diam. 8 in. to 8 1/2 ft. depth Weight 160 lbs./ft. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
2		Type and color of material			From	To	8 Screen: Manufacturer Certain-Tee Type PVC Dia. 8" Slot/gauge 3/16" drill length 30' Set between 37' and 68' Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/4" 1/2"
		Top soil			0	2	9 Static water level: 22 ft. below land surface Date 10-11-76
		Clay silty Brn.			2	15	10 Pumping level below land surfaces: 24 ft. after 3 hrs. pumping 30 g.p.m. 24 ft. after 3 hrs. pumping 30 g.p.m. Estimated maximum yield 45 g.p.m.
		Clay sandy Brn			15	18	11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____
		Sand v Fine Brn			18	34	12 Well head completion: NO <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade
		Sand M. Fine Brn			34	45	13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 3 ft. to 13'
		Sand C coarse Brn.			45	67	14 Nearest source of possible contamination: ft 60 Direction North creek Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
							15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
							16 Remarks: elevation 1670 top Topography: 1/4 m <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley Pump & concrete slab to be installed by customer he know this is a regulation
							17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Arnold Water Well Drilling Business name 506 S Morgan St. License No. _____ Address Robert Arnold Date _____ Signed _____ Authorized representative

20 8 W 16
S N W SW