USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD KSA 82a-1201-1215 plos

Kansas Department of Health and Environment-Division of Environment (Water well Contractors) Topeka, Kansas 66620

	County	Fraction		Section r	number	Township number	Range number	
1. Location of well:	Rice	SW 1/4 SW1/4 NW	1/4	26	3	т 20 s	R 8	
					ner of well: Bruce Walton			
4½ miles Southeast of Lyons, KS R.R. or street: Street address of well location if in city:					Route 2			
Street address of well location it in city: City, state, zip code: S					ode: St	erling, KS 675		
4. Locate with "X" in section below: Sketch map:				6. Bore hole dia. 24 in. Completion date 3-9-79 Well depth 60 ft. Pump Set X 4-6-79				
2600' South and 1260' East of NW Corner of Sec. 26					7 Cable tool X Rotary Driven Dug			
					X Irrigation Air conditioning Stock Lawn Oil field water Other			
						Threaded Welded X Surface 12 in. RMP PVC Weight 30.3 lbs./ft. Dia 16 in. to 20 ft. depth Wall Thickness: inches or		
\$								
I ← 1 Mile ← → I				From	То	Diain. to ft. dept	h gage No. 7 ga.	
5. Type and color of	rmaterial			11011	10	10. Screen: Manufacturer's n	ome W. A. Brown	
Sand				0	20	Double-slot	Dia 16''	
				9	12	Slot gauze 1/8"	_ Length	
Sand clay	у			"	12	Set between <u>20</u>		
Sand & gravel			12	30	ft. a Gravel pack? <u>Yes</u> Size rai	nge of material 3/8-200		
Brown clay				30	34	11. Static water level: 10'6" ft. below land sur		
Cond C grovel				34	49		surfaces: Not Checked	
Sand & gravel				34	43	ft. after h	rs. pumping g.p.m.	
Brown & white clay & limestone & gravel streak				s 49	59	ft. after h		
Red shale				59	60	Estimated maximum yield 13. Water sample submitted:		
red Share				00	- 00	Yes X No		
						14. Well head completion:		
						Pitless adapter <u>1</u>	2 Inches above grade	
				 		15. Well grouted? Yes		
						With: X Neat cement Depth: From0 ft. to .	Bentonite Concrete 10 ft.	
				ļ		16. Nearest source of possible		
						Well disinfected upon comple	tion? Yes X No	
						17. Pump: Manufacturer's name Peer	Not installed	
				\vdash		Model number1215-3	HP 80 Volts	
						Length of drop pipe 50	ft. capacity 800g.p.m.	
						Type: Submersible	X Turbine	
						Jet	Reciprocating	
(Use a second sheet if needed)						Centrifugal	Other	
18. Elevation: 19. Remarks:						20. Water well contractor's o		
					This well was drilled under my is true to the best of my know	' '		
Topography:					Clarke Well & E	· · · · · · · · · · · · · · · · · · ·		
Hill					Rusi pess name	License No.		
Slope						Address Great Bend	4-10-79	
Upland Valley						Signed Authorized rep	Date —	
Valley	l							