

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

WELL AND #1

1. Location of well:	County: RICE	Fraction: C 1/4 NE 1/4 NE 1/4	Section number: 5	Township number: T 20 S R 9 E/W	Range number:
2. Distance and direction from nearest town or city: 1 MILE EAST			3. Owner of well: EMPHIS DRILLING CO		
Street address of well location if in city: 1/4 SOUTH CHASE,			R.R. or street: RUSSELL KANSAS City, state, zip code:		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 7 in. Completion date 2-21-77 Well depth 60 ft.	
				7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other	
				9. Casing: Material PLASTIC Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight 207-3 lbs./ft. Dia. 4 in. to 60 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. SCRD 40	
5. Type and color of material		From	To	10. Screen: Manufacturer's name SELF MADE	
CLAY		0	20	Type PVC Dia. 4 Slot gauge 1/8 Length 20 Set between 40 ft. and 60 ft. ft. and ft.	
SANDY LOAM		20	40	Gravel pack? YES Size range of material 1/2 3/4	
GRAVEL		40	60	11. Static water level: <input checked="" type="checkbox"/> mo./day/yr. 19 ft. below land surface Date 2-21-77	
				12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
				13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
				14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade	
				15. Well grouted? YES With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
				16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
		(Use a second sheet if needed)			
18. Elevation:	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. MYERS WATER WELL 143 Business name _____ License No. _____ Address GARRET BEND KANS. Signed Dwayne Chabon Date 2/24/77 Authorized representative	
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

T 20 S R 9 E W 5 C NE NE 1/4 1/4 1/4