USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Rice	NW 1/4 NW 1/4 NE 1/4	24	T 20 S	R 9 E/W

2. Distance and direction from nearest town or city: 2S. 3W Lyons
Street address of well location if in city:

3. Owner of well: Kenneth Knight
R.R. or street: RR 1
City, state, zip code: Lyons, Kans.

4. Locate with "X" in section below:



Sketch map:

6. Bore hole dia. 28 in. Completion date 8/7/75
Well depth 58 ft.

7. __ Cable tool __ Rotary __ Driven __ Dug
__ Hollow rod __ Jetted __ Bored X Reverse rotary

8. Use: __ Domestic __ Public supply __ Industry
X Irrigation __ Air conditioning __ Stock
__ Lawn __ Oil field water __ Other

9. Casing: Material Transite Weight: Above or below
Threaded ___ Welded ___ Surface 12 in.
RMP ___ PVC ___ Weight 30 lbs./ft.
Dia. 16 in. to 32 ft. depth Wall Thickness: inches or
Dia. ___ in. to ___ ft. depth gage No. 34

5. Type and color of material	From	To
Top soil	0	2
Yellow/brown clay	2	4½
Sand and gravel	4½	12
Brown clay	12	14
Gravel(clean,coarse,loose)	14	33
Brown/gray clay	33	37
Sand and gravel(clean,loose)	37	55
Clay	55	77
Fine sand	77	80
Brown and white clay	80	140
Sandy brown clay	140	150
Sandy clay	150	160
(Use a second sheet if needed)		

10. Screen: Manufacturer's name Johnson
Type Naweld Dia. 16
Slot/gauze 3/16 Length 24
Set between 32 ft. and 58 ft.
___ ft. and ___ ft.
Gravel pack? yes Size range of material 1/8-¼

11. Static water level: mo./day/yr.
8 ft. below land surface Date 7/11/75

12. Pumping level below land surfaces:
42 ft. after 1 hrs. pumping 1000 g.p.m.
36 ft. after ½ hrs. pumping 600 g.p.m.
Estimated maximum yield ___ g.p.m.

13. Water sample submitted: mo./day/yr.
Yes X No Date

14. Well head completion:
___ Pitless adapter ___ Inches above grade

15. Well grouted? yes
With: ___ Neat cement XX Bentonite ___ Concrete
Depth: From ___ ft. to ___ ft.

16. Nearest source of possible contamination:
ft. ___ Direction ___ Type ___
Well disinfected upon completion? ___ Yes X No

17. Pump: ___ Not installed
Manufacturer's name Fairbanks-Morse
Model number 7-12 AA HP 60 Volts 440
Length of drop pipe 140 ft. capacity 1000 g.p.m.
Type:
___ Submersible XX Turbine
___ Jet ___ Reciprocating
___ Centrifugal ___ Other

18. Elevation:

Topography:
___ Hill
___ Slope
X Upland
___ Valley

19. Remarks:

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Darling Drilling Co. 189
Business name License No.
Address 1911 W. 4th Hutchinson, Ks.
Signed Donald Darling Date 8-7-75
Authorized Representative

T R W Sec 1/4 1/4 1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5