

USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Fluoride #

1. Location of well: County Rice Fraction N 1/2 S 1/4 Section number 29 Township number T 20 S R 9 Range number E/W

2. Distance and direction from nearest town or city: CHASE
Street address of well location if in city: 1/4 SOUTH 1/4 EAST
3. Owner of well: Allen Delg. Co
R.R. or street:
City, state, zip code: GREAT BEND KS

4. Locate with "X" in section below: Sketch map:

6. Bore hole dia. 9 in. Completion date 2-17-78
Well depth 60 ft.
7. Cable tool Rotary Driven Dug
 Hollow rod Jetted Bored Reverse rotary
8. Use: Domestic Public supply Industry
 Irrigation Air conditioning Stock
 Lawn Oil field water Other
9. Casing: Material _____ Height: Above or below
Threaded _____ Welded Surface 12 in.
RMP _____ PVC Weight 278-3 lbs./ft.
Dia. 5 in. to 60 ft. depth Wall Thickness: inches or
Dia. _____ in. to _____ ft. depth gage No. 300

5. Type and color of material	From	To
<u>Clay</u>	<u>0</u>	<u>10</u>
<u>Fine Sand</u>	<u>10</u>	<u>30</u>
<u>Clay</u>	<u>30</u>	<u>40</u>
<u>Gravel</u>	<u>40</u>	<u>60</u>

10. Screen: Manufacturer's name Pusher
Shop made
Type Saw Dia. 5
Slot/gauze 1/8 Length 20
Set between 40 ft. and 60 ft.
Gravel pack? Size range of material 1/4-1/8
11. Static water level: _____ mo./day/yr.
28 ft. below land surface Date 7-17-78
~~12.~~ Pumping level below land surfaces:
_____ ft. after _____ hrs. pumping _____ g.p.m.
_____ ft. after _____ hrs. pumping _____ g.p.m.
Estimated maximum yield _____ g.p.m.
13. Water sample submitted: _____ mo./day/yr.
Yes _____ No _____ Date _____
14. Well head completion:
 Pitless adapter 12 Inches above grade
15. Well grouted? yes
With: _____ Neat cement Bentonite _____ Concrete
Depth: From 0 ft. to 40 ft.
 Nearest source of possible contamination:
ft. _____ Direction _____ Type _____
Well disinfected upon completion? _____ Yes _____ No
17. Pump: _____ Not installed
Manufacturer's name _____
Model number _____ HP _____ Volts _____
Length of drop pipe _____ ft. capacity _____ g.p.m.
Type:
 Submersible Turbine
 Jet Reciprocating
 Centrifugal Other

18. Elevation:
Topography:
 Hill
 Slope
 Upland
 Valley
19. Remarks:
(Use a second sheet if needed)

20. Water well contractor's certification:
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.
Myers Water Wells
Business name GT Bend KS License No. _____
Address _____
Signed Floyd Rosendahl Date 2-17-78
Authorized representative