


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

<input checked="" type="checkbox"/> Location of well:	County <b>Rice</b>	Fraction <b>North 1/2</b> 1/4 1/4 SW 1/4	Section number <b>1</b>	Township number T <b>21</b> S R	Range number <b>10</b> <span style="float:right;">EW</span>
2. Distance and direction from nearest town or city: <b>3 1/2 miles West of Alden, KS</b> Street address of well location if in city:			3. Owner of well: <b>Fred Fair</b> R.R. or street: <b>(?)</b> City, state, zip code: <b>Alden, KS 67512</b>		
4. Locate with "X" in section below: <div style="text-align: center;">  <p style="text-align: center;">1 Mile</p> </div>			Sketch map: <b>NOTE: Six identical wells completed in same area for manifold hook-up. One form filed for all six wells. The wells are approx. 50' apart-- NE - SW direction.</b>		
5. Type and color of material			From	To	6. Bore hole dia. <u>24</u> in. Completion date <b>12-16-76</b> Well depth <u>32</u> ft. (each)
<b>top soil</b>			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
<b>sand &amp; gravel</b>			3	29	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
<b>gray &amp; blue clay</b>			29	32	9. Casing: Material <u>steel</u> Height: <input checked="" type="checkbox"/> Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>30.3</u> lbs./ft. Dia. <u>16</u> in. to <u>12</u> ft. depth Wall Thickness: inches or Dia. <u>   </u> in. to <u>   </u> ft. depth Gauge No. <u>7 ga.</u>
					10. Screen: Manufacturer's name <u>Doerr</u> Type <u>Double-slot</u> Dia. <u>16"</u> <input checked="" type="checkbox"/> Slot gauze <u>1/8"</u> Length <u>20'</u> Set between <u>12</u> ft. and <u>32</u> ft. <u>   </u> ft. and <u>   </u> ft. Gravel pack? <u>yes</u> Size range of material <u>3/8-200</u>
					11. Static water level: <u>9'6"</u> ft. below land surface Date <u>11-3-76</u> mo./day/yr.
					12. Pumping level below land surfaces: <u>N/C</u> <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>   </u> g.p.m.
					13. Water sample submitted: <u>   </u> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u>   </u>
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade
					15. Well grouted? <u>yes</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: ft. <u>   </u> Direction <u>   </u> Type <u>   </u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: <input type="checkbox"/> Not installed Manufacturer's name <u>Berkeley Pump Co.</u> Model number <u>B4 IRBM</u> HP <u>40</u> Volts <u>460</u> Length of drop pipe <u>30'</u> ft. capacity <u>800</u> g.p.m. Type: <u>each well</u> <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					
18. Elevation:  Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:  <b>Water quality not suitable for irrigation at depth below 40'.</b>  <u>   </u>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Clarke Well &amp; Equip., Inc 185</b> Business name License No. Address <b>Great Bend, KS 67530</b> Signed <u>D.H. Clarke</u> Date <b>12-29-76</b> Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5