


USE TYPEWRITER OR BALL POINT PEN-PRESS FIRMLY, PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County <u>Free</u>	Fraction <u>NE 1/4 NW 1/4 SW 1/4</u>	Section number <u>14</u>	Township number <u>T 21 N</u>	Range number <u>S R 10 E/W</u>
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <u>Stelling Hardware Co</u> R.R. or street: City, state, zip code: <u>Stelling, Iowa</u>		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. <u>9</u> in. Completion date <u>10-16-76</u> Well depth <u>60</u> ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool & Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
From			9. Casing: Material <u>Galv</u> Height: Above or below Threaded <u>None</u> Surface <u>1 1/2</u> in. RMP <u>PVC</u> Weight <u>71.6</u> lbs./ft. Dia. <u>2</u> in. to <u>70</u> ft. depth Wall thickness <u>inches</u> or Dia. <u>in.</u> to <u>ft.</u> depth gage No. <u>500-40</u>		
			10. Screen: Manufacturer's name <u>Slip Made</u> Type <u>Slot</u> Dia. <u>2</u> Slot/gauze <u>10</u> Length <u>10</u> Set between <u>50</u> ft. and <u>60</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>1/4"</u>		
			11. Static water level: <u>14</u> ft. below land surface Date <u>10-16-76</u> mo./day/yr.		
			12. Pumping level below land surfaces: <u>16</u> ft. after <u>3</u> hrs. pumping <u>70</u> g.p.m. <u>ft.</u> after <u>hrs.</u> pumping <u>g.p.m.</u> Estimated maximum yield <u>100</u> g.p.m.		
			13. Water sample submitted: <u>Yes</u> <input checked="" type="checkbox"/> <u>No</u> <input type="checkbox"/> Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <u>1 1/2</u> inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>ft.</u> to <u>ft.</u>		
			16. Nearest source of possible contamination: ft. <u>Direction</u> <u>Type</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Myers Water Well Service</u> Business name License No. <u>143</u> Address <u>143</u> Signed <u>[Signature]</u> Date <u>10-16-76</u> Authorized representative		
18. Elevation:		19. Remarks:			
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

21
 10
 14
 NE 1/4 SW 1/4