


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County <u>STAFFORD</u>	Fraction <u>NW 1/4 NE 1/4 NW 1/4</u>	Section number <u>1</u>	Township number <u>T 21 S</u>	Range number <u>R 11 E</u>
2. Distance and direction from nearest town or city:	3. Owner of well: <u>Sterling Supply Co</u>				
Street address of well location if in city:	R.R. or street: <u>West Raymond St</u>				
4. Locate with "X" in section below:			City, state, zip code: <u>Stirling Kansas</u>		
Sketch map: 			6. Bore hole dia. <u>5</u> in. Completion date <u>9-2-76</u> Well depth <u>95</u> ft.		
5. Type and color of material			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input checked="" type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Steel</u> Height: Above or below Threaded <u>Welded</u> Surface <u>12</u> in. RMP <u>PVC</u> Weight <u>71.6</u> lbs./ft. Dia. <u>2</u> in. to <u>25</u> ft. depth Wall Thickness: inches or Dia. <u>2</u> in. to <u>25</u> ft. depth gage No. <u>40-154</u>		
			10. Screen: Manufacturer's name <u>Shaw-Walker</u> Type <u>PVC</u> Dia. <u>2</u> Slot/gauze <u>1/8"</u> Length <u>10</u> Set between <u>85</u> ft. and <u>95</u> ft. ft. and <u>95</u> ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material <u>4-14</u>		
			11. Static water level: <u>8</u> mo./day/yr. <u>10</u> ft. below land surface Date <u>9-2-76</u>		
(Use a second sheet if needed)			12. Pumping level below land surfaces: <u>15</u> ft. after <u>1</u> hrs. pumping <u>60</u> g.p.m. <u>   </u> ft. after <u>   </u> hrs. pumping <u>   </u> g.p.m. Estimated maximum yield <u>100</u> g.p.m.		
			13. Water sample submitted: <u>   </u> mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date <u>   </u>		
			14. Well head completion: <u>   </u> Pitless adapter <u>12</u> Inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> With: <input checked="" type="checkbox"/> Neat cement <u>   </u> Bentonite <u>   </u> Concrete <u>   </u> Depth: From <u>0</u> ft. to <u>20</u> ft.		
			16. Nearest source of possible contamination: ft. <u>   </u> Direction <u>   </u> Type <u>   </u> Well disinfected upon completion? <u>   </u> Yes <u>   </u> No		
18. Elevation:			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u>   </u> Model number <u>   </u> HP <u>   </u> Volts <u>   </u> Length of drop pipe <u>   </u> ft. capacity <u>   </u> g.p.m. Type: <u>   </u> Submersible <u>   </u> Turbine <u>   </u> Jet <u>   </u> Reciprocating <u>   </u> Centrifugal <u>   </u> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <u>Myers Water Well Service</u> Business name <u>   </u> License No. <u>143</u> Address <u>West Raymond St</u> Signed <u>Charles C Myers</u> Date <u>9-30-76</u> Authorized representative		
			19. Remarks:		
			Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5